



Excavation at side of raw water main culvert to confirm pipe bedding material on 07/09/2023.

This was following a request from Stephen McCann - Rochdale Council in the consultee correspondence dated 01/09/2023.

This also confirms pipe material as concrete, but is also confirmed in the CCTV survey of this culverted dated April 2021, which has also been submitted in support of the discharge of planning condition 6



GPS data take at location of the raw water main excavation