Drawing Copyright © of Banyard Consultants Ltd.





42w 5M POLE MOUNTED LED LUMINAIRE WITH 0% UPLIGHT



LED WALL MOUNTED LUMINAIRE WITH 0% UPLIGHT



ASYMMETRICAL 1.8M TALL LED BOLLARD WITH 0% UPLIGHT

NOTE:
ALL LUMINAIRES TO BE CONTROLLED VIA A PHOTOCELL AND TIMECLOCK ARRANGEMENT. WALL MOUNTED MOVEMENT SENSORS SHALL BE EMPLOYED TO ACTIVATE LIGHTING DURING 'OUT OF HOURS' OPERATION TO ENHANCE CCTV CAMERA IDENTIFICATION OF TRESPASSER.

AN OVERRIDE SWITCH SHALL BE PROVIDED TO ALLOW MANUAL CONTROL OF LUMINAIRE INCASE OF NUISANCE TRIPPING

ALL FUNCTIONAL LIGHTING SHALL BE CAPABLE OF 'DARK SKY COMPLIANCE'

Rev.	Description	App.	Chk.	Drn.	Date
P1	FOR PLANNING	RH	RH / AP	AP	13.03.18

Client

Project
Kirkholt Health Centre

Drawing Title
External Lighting Layout

Banyard consultants
Banyard Consultants Ltd.
Telephone: 01732 467000, Facsimile: 01732 465758
E-mail: consultants@banyards.co.uk Website: www.banyards.co.uk
Somerhill House, Somerhill Business Park, Five Oak Green Rd, Tonbridge, Kent TN11 0GP

Status
Preliminary

X:\7800-7899\7...\Cad\E\7862-BCL-00-EX-DR-E2101.dwg

Scale 1:200 @A3 Discipline M&E

Drawing Number
7862-BCL-00-EX-DR-E2101

Revision
P1