

Legend:

X1

X2

External bracket mounted LED Floodlight  
c/w 4000k colour temperature output  
mounted approx 5500mm AFFL

X2

X2

External wall mounted LED downlight  
c/w 2700k colour temperature output  
mounted approx 3000mm AFFL

EXIT

External wall mounted LED non-maintained  
emergency overdoor bulkhead c/w 4500k colour  
temperature output mounted approx 2500mm AFFL

©This drawing and its contents  
are strictly the copyright of GLD

ISO 9001

REGISTERED

MANAGEMENT

SYSTEMS

UKAS

MANAGEMENT

SYSTEMS

0026

Certificate Number 16602-Q15-001

ISO 9001

General Notes

1. Drawings are to be read in conjunction with all relevant specifications, engineers, architects & services drawings, including approved builders work drawings. Contractor to notify engineer of discrepancies between structural drawings & specifications or other drawings.

2. All dimensions are in millimeters unless noted otherwise.

3. Do not scale from the drawings or the computer digital data, only figured dimensions are to be used.

Proposed lighting Layout Plan  
Scale 1:200@A1

Proposed Luminaire Schedule

| Luminaire Reference | Luminaire Description                                                                                                                                                                                                                                          | Lamp Type                                    | Proposed Location                         | Proposed Luminaire |
|---------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|-------------------------------------------|--------------------|
| X1                  | IP66 IK10 rated 320mmx190mmx62mm LED bracket surface mounted wall luminaires, c/w die cast aluminium silver body; toughened glass lens; wide flood distribution; high frequency LED control gear.<br><br>As LDL Lighting Cora range or accepted and equivalent | 53w<br>4283 lm<br>4000K<br>RA 80+<br>L90/B10 | Front and rear loading areas              |                    |
| X2                  | IP65 IK08 rated 230mmx220mmx220mm LED surface mounted wall luminaires, c/w die cast aluminium graphite body; toughened glass lens; wide downlight distribution; high frequency LED control gear.<br><br>As LDL Lighting Luna range or accepted and equivalent  | 14w<br>1205 lm<br>2700K<br>RA 80+<br>L90/B10 | Side elevation serving perimeter pathways |                    |
| E1                  | IP65 IK06 rated 350mm x 120mm x 90mm deep LED emergency bulkhead luminaire c/w 3 hour duration non-maintained integral battery; clear polycarbonate TP(a) opal lens, black body.<br><br>As LDL AX range or accepted and equivalent                             | 150 lm<br>4500K<br>L90/B10                   | External Exits                            |                    |

Proposed Elevation A  
Scale 1:200@A1

Proposed Elevation C  
Scale 1:200@A1

Proposed Elevation B  
Scale 1:200@A1

Proposed Elevation D  
Scale 1:200@A1

©This drawing and its contents  
are strictly the copyright of GLD

ISO 9001

REGISTERED

MANAGEMENT

SYSTEMS

UKAS

MANAGEMENT

SYSTEMS

0026

Certificate Number 16602-Q15-001

ISO 9001

General Notes

1. Drawings are to be read in conjunction with all relevant specifications, engineers, architects & services drawings, including approved builders work drawings. Contractor to notify engineer of discrepancies between structural drawings & specifications or other drawings.

2. All dimensions are in millimeters unless noted otherwise.

3. Do not scale from the drawings or the computer digital data, only figured dimensions are to be used.

P1 | 04-Mar-2024 | Preliminary Issue | JasW | GD

Rev | Date | Amendment | Drawn | Ckd

Drawn By: JasW | Drawn Date: 04 Mar 2024 | Scale: 1:200 @ A1

Checked By: GD | Checked Date: 04 Mar 2024 | xRef: 20240216-Existing-Site-Plan

Client: 

MAGIO TOYS

Project Title: Station Road, Milnrow, Oldham

Drawing Title: Site Plan - Proposed External Lighting Elevation

Status: Preliminary

GLD

TECHNICAL CONSULTING LTD

Domhouse, Astley Hall Drive  
Astley, Manchester, M29 7TX  
W: [www.gldtechnicalconsulting.co.uk](http://www.gldtechnicalconsulting.co.uk)  
T: 01942889535 / 01616417097

Drawing No: J384-GLD-GF-DR-E-8000-003 | Rev P1