




proposed ground floor plan



The sewer running under the extension will require surveying to check depth and size of pipe, please see attached matrix on whether formal application for build over is required to UU.				
Depth to sewer	Total length of sewer built over or within 3m of centre line			
	0 – 0.6m	0.6 – 0.8m	0.8 – 1.0m	10.0 – 12.0m
>12.0m				>12.0m
6 – 1.2m				
1.2 – 2.0m				
2.0 – 3.0m				
>3.0m				
All work to comply with Part H4 of Building Regulations – no further approval from UUW required All work to comply with Part H4 of Building Regulations – no further approval from UUW required (in accordance with Section 1.5 of Part H4 UUW agree in advance to the length of sewer built over, or within 3m of, can be greater than 0.6m) Formal building over agreement required				
Notes:	1. This matrix applies to sewers less than 300mm in diameter only. Any sewer 300mm diameter or greater automatically require a building over agreement 2. The length of sewer built over is cumulative, and will include any length already built over prior to any proposed extension.			

proposed first floor plan



JOB No. _____ REV. _____