

T J Booth Associates		Page 1
104 Yorkshire St Rochdale Lancashire OL16 1JY	attenuation 100yr+20% sartex quilts castle mill rear yard	
Date jan 2023 File calc-tjba-sartex-castle mill-site atte...	Designed By ds Checked By	
Micro Drainage	Source Control W.10.4	

Summary of Results for 100 year Return Period (+20%)

Storm Duration (mins)	Maximum Control (l/s)	Maximum Overflow (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Overflow Volume (m ³)	Maximum Volume (m ³)	Status
15 Summer	5.0	0.0	5.0	146.7782	0.4682	0.0	37.5	O K
30 Summer	5.0	0.0	5.0	146.9917	0.6818	0.0	54.5	O K
60 Summer	5.0	0.0	5.0	147.1463	0.8363	0.0	66.9	O K
120 Summer	5.0	0.0	5.0	147.1878	0.8778	0.0	70.2	O K
180 Summer	5.0	0.0	5.0	147.2158	0.9058	0.0	72.5	O K
240 Summer	5.0	0.0	5.0	147.1993	0.8893	0.0	71.1	O K
360 Summer	5.0	0.0	5.0	147.1638	0.8538	0.0	68.3	O K
480 Summer	5.0	0.0	5.0	147.1223	0.8123	0.0	65.0	O K
600 Summer	5.0	0.0	5.0	147.0758	0.7658	0.0	61.3	O K
720 Summer	5.0	0.0	5.0	147.0267	0.7168	0.0	57.3	O K
960 Summer	5.0	0.0	5.0	146.9117	0.6018	0.0	48.2	O K
1440 Summer	5.0	0.0	5.0	146.6977	0.3877	0.0	31.0	O K
2160 Summer	5.0	0.0	5.0	146.4897	0.1797	0.0	14.4	O K
2880 Summer	4.8	0.0	4.8	146.3842	0.0743	0.0	6.0	O K
4320 Summer	4.1	0.0	4.1	146.3107	0.0008	0.0	0.1	O K
5760 Summer	3.3	0.0	3.3	146.3100	0.0000	0.0	0.0	O K
7200 Summer	2.8	0.0	2.8	146.3100	0.0000	0.0	0.0	O K
8640 Summer	2.4	0.0	2.4	146.3100	0.0000	0.0	0.0	O K
10080 Summer	2.2	0.0	2.2	146.3100	0.0000	0.0	0.0	O K
15 Winter	5.0	0.0	5.0	146.8483	0.5382	0.0	43.1	O K
30 Winter	5.0	0.0	5.0	147.0888	0.7788	0.0	62.3	O K
60 Winter	5.0	0.0	5.0	147.2308	0.9208	0.0	73.7	O K
120 Winter	5.0	0.0	5.0	147.3863	1.0763	0.0	86.1	O K
180 Winter	5.0	0.0	5.0	147.3833	1.0733	0.0	85.9	O K
240 Winter	5.0	0.0	5.0	147.3543	1.0443	0.0	83.6	O K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
15 Summer	89.23	18
30 Summer	61.54	34
60 Summer	40.51	64
120 Summer	25.63	120
180 Summer	19.23	154
240 Summer	15.63	188
360 Summer	11.65	254
480 Summer	9.44	326
600 Summer	8.01	394
720 Summer	7.00	464
960 Summer	5.65	598
1440 Summer	4.17	838
2160 Summer	3.07	1172
2880 Summer	2.46	1504
4320 Summer	1.81	2200
5760 Summer	1.45	0
7200 Summer	1.23	0
8640 Summer	1.07	0
10080 Summer	0.95	0
15 Winter	89.23	18
30 Winter	61.54	34
60 Winter	40.51	60
120 Winter	25.63	118
180 Winter	19.23	170
240 Winter	15.63	196

T J Booth Associates		Page 2
104 Yorkshire St Rochdale Lancashire OL16 1JY	attenuation 100yr+20% sartex quilts castle mill rear yard	
Date jan 2023 File calc-tjba-sartex-castle mill-site atte...	Designed By ds Checked By	
Micro Drainage		Source Control W.10.4

Summary of Results for 100 year Return Period (+20%)

Storm Duration (mins)	Maximum Control (l/s)	Maximum Overflow (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Overflow Volume (m ³)	Maximum Volume (m ³)	Status
360 Winter	5.0	0.0	5.0	147.2998	0.9898	0.0	79.2	O K
480 Winter	5.0	0.0	5.0	147.2343	0.9243	0.0	74.0	O K
600 Winter	5.0	0.0	5.0	147.1613	0.8513	0.0	68.1	O K
720 Winter	5.0	0.0	5.0	147.0833	0.7733	0.0	61.9	O K
960 Winter	5.0	0.0	5.0	146.8978	0.5878	0.0	47.0	O K
1440 Winter	5.0	0.0	5.0	146.5802	0.2702	0.0	21.6	O K
2160 Winter	4.7	0.0	4.7	146.3642	0.0543	0.0	4.4	O K
2880 Winter	4.0	0.0	4.0	146.3100	0.0000	0.0	0.0	O K
4320 Winter	3.0	0.0	3.0	146.3100	0.0000	0.0	0.0	O K
5760 Winter	2.4	0.0	2.4	146.3100	0.0000	0.0	0.0	O K
7200 Winter	2.0	0.0	2.0	146.3100	0.0000	0.0	0.0	O K
8640 Winter	1.8	0.0	1.8	146.3100	0.0000	0.0	0.0	O K
10080 Winter	1.6	0.0	1.6	146.3100	0.0000	0.0	0.0	O K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
360 Winter	11.65	274
480 Winter	9.44	350
600 Winter	8.01	428
720 Winter	7.00	504
960 Winter	5.65	644
1440 Winter	4.17	866
2160 Winter	3.07	1160
2880 Winter	2.46	0
4320 Winter	1.81	0
5760 Winter	1.45	0
7200 Winter	1.23	0
8640 Winter	1.07	0
10080 Winter	0.95	0

T J Booth Associates		Page 3
104 Yorkshire St Rochdale Lancashire OL16 1JY	attenuation 100yr+20% sartex quilts castle mill rear yard	
Date jan 2023 File calc-tjba-sartex-castle mill-site atte...	Designed By ds Checked By	
Micro Drainage	Source Control W.10.4	

Rainfall Details

Region	ENG+WAL	Shortest Storm (mins)	15
Return Period (years)	100	Longest Storm (mins)	10080
M5-60 (mm)	20.000	Summer Storms	Yes
Ratio-R	0.300	Winter Storms	Yes
Cv (Summer)	0.750	Climate Change %	+20
Cv (Winter)	0.840		

Pipe Network

Volume in Pipe Network (m ³)	4	Dia of Outfall Pipe (m)	0.200
Slope of Outfall Pipe (1:x)	100.0	Roughness of Outfall Pipe	0.600

Time / Area Diagram

Total Area (ha) = 0.230

Time	(mins)	Area
from:	to:	(ha)
0	4	0.230

T J Booth Associates		Page 4
104 Yorkshire St Rochdale Lancashire OL16 1JY	attenuation 100yr+20% sartex quilts castle mill rear yard	
Date jan 2023 File calc-tjba-sartex-castle mill-site atte...	Designed By ds Checked By	
Micro Drainage	Source Control W.10.4	

Tank/Pond Details

Invert Level (m) 146.310 Ground Level (m) 148.430

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.00	80.0	0.50	80.0	1.00	80.0	1.50	80.0	2.00	80.0	2.50	80.0
0.10	80.0	0.60	80.0	1.10	80.0	1.60	80.0	2.10	80.0		
0.20	80.0	0.70	80.0	1.20	80.0	1.70	80.0	2.20	80.0		
0.30	80.0	0.80	80.0	1.30	80.0	1.80	80.0	2.30	80.0		
0.40	80.0	0.90	80.0	1.40	80.0	1.90	80.0	2.40	80.0		

Depth / Flow Outflow Control

Invert Level of Control 146.160

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.10	3.4	0.80	4.1	2.00	6.4	4.00	9.1	7.00	12.1
0.20	4.7	1.00	4.5	2.20	6.8	4.50	9.7	7.50	12.5
0.30	5.0	1.20	4.9	2.40	7.1	5.00	10.2	8.00	12.9
0.40	5.0	1.40	5.3	2.60	7.4	5.50	10.7	8.50	13.3
0.50	4.9	1.60	5.8	3.00	7.9	6.00	11.2	9.00	13.7
0.60	4.8	1.80	6.1	3.50	8.5	6.50	11.6	9.50	14.1

Pipe Overflow Control

Pipe Diameter (m)	0.150	Entry Loss Coef	0.500
Slope (1:x)	100.0	Coef of Contraction	0.600
Length (m)	10.000	Invert Level (m)	147.390
Roughness (mm)	0.600		