

Project name

Unit J2 Kingsway Business Park**As built****Date:** Thu Oct 10 15:26:00 2024

Administrative information

Building Details

Address: Unit J2, James Kearns Avenue, Kingsway
Business Park, Rochdale, OL16 4NZ

Certifier details

Name: Mohammed Fatade**Telephone number:** 0113 233 8028**Address:** BWB Consulting Limited, Whitehall Waterfront, 2
Riverside Way, Leeds, LS1 4EH

Certification tool

Calculation engine: Apache**Calculation engine version:** 7.0.26**Interface to calculation engine:** IES Virtual Environment**Interface to calculation engine version:** 7.0.26**BRUKL compliance module version:** v6.1.e.1**Foundation area [m²]:** 10985.3The CO₂ emission and primary energy rates of the building must not exceed the targets

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	2.52
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	1.98
Target primary energy rate (TPER), kWh _{PE} /m ² annum	25.5
Building primary energy rate (BPER), kWh _{PE} /m ² annum	19.5
Do the building's emission and primary energy rates exceed the targets?	BER ≤ TER BPER ≤ TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _{a-Limit}	U _{a-Calc}	U _{i-Calc}	First surface with maximum value
Walls*	0.26	0.25	0.25	00000019:Surf[1]
Floors	0.18	0.12	0.12	00000019:Surf[0]
Pitched roofs	0.16	-	-	No pitched roofs in building
Flat roofs	0.18	0.18	0.18	00000000:Surf[57]
Windows** and roof windows	1.6	1.2	1.2	00000017:Surf[1]
Rooflights***	2.2	1.3	1.3	00000000:Surf[31]
Personnel doors^	1.6	1.6	1.6	00000005:Surf[1]
Vehicle access & similar large doors	1.3	1.23	1.3	00000000:Surf[7]
High usage entrance doors	3	-	-	No high usage entrance doors in building
U _{a-Limit} = Limiting area-weighted average U-values [W/(m ² K)] U _{a-Calc} = Calculated area-weighted average U-values [W/(m ² K)] U _{i-Calc} = Calculated maximum individual element U-values [W/(m ² K)] * Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. ** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position. ^ For fire doors, limiting U-value is 1.8 W/m ² K NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	2.38

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	0.9 to 0.95

1- 002_220810_ASHP (REYA10A-12A) VAM500

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	4.41	7.17	0	1.23	0.73
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

2- 004_220810_Electric Panel Heater

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	1	-	0.67	-	-
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO

3- 008_220810_Air Source Heat Pump (Shell)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	2.5	-	0	-	-
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO

4- 001_220810_ASHP (REYA10A-12A) VAM350

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	4.41	7.17	0	0.99	0.77
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

5- 003_220810_ASHP (REYA10A-12A) VAM1000

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	4.41	7.17	0	1.47	0.73
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

6- 000_220810_ASHP (REYA10A-12A)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	4.41	7.17	0	-	-
Standard value	2.5*	5	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

1- 006_220810_Electric DHW (10L)

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	0.063
Standard value	1	N/A

2- 009_220810_Instant Electric DHW (Shell)

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	-
Standard value	1	N/A

3- 007_220810_Electric DHW (15L)

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	0.047
Standard value	1	N/A

4- 005_220810_Electric DHW (5L)

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	0.102
Standard value	1	N/A

Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter
NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.	

Zone name	SFP [W/(l/s)]										HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I		Zone	Standard
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1			
00_Plot J2_Unit J2_GF WC	-	-	0.7	-	-	-	-	-	-	-	-	N/A
01_Plot J2_Unit J2_FF Female WC	-	-	0.4	-	-	-	-	-	-	-	-	N/A
01_Plot J2_Unit J2_FF Male WC	-	-	0.4	-	-	-	-	-	-	-	-	N/A
01_Plot J2_Unit J2_FF Office Tea	0.3	-	-	-	-	-	-	-	-	-	-	N/A
01_Plot J2_Unit J2_FF WC	-	-	0.4	-	-	-	-	-	-	-	-	N/A

General lighting and display lighting

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
Standard value		95	80	0.3
00_Plot J2_Unit J2_GF Cleaners		142	-	-
00_Plot J2_Unit J2_GF Lift		95	-	-
00_Plot J2_Unit J2_GF Lobby		127	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
00_Plot J2_Unit J2_GF Stairs		133	-	-
00_Plot J2_Unit J2_GF Stairs		127	-	-
00_Plot J2_Unit J2_GF Store		95	-	-
00_Plot J2_Unit J2_GF WC		113	-	-
00_Plot J2_Unit J2_Warehouse		95	-	-
01_Plot J2_Unit J2_FF Female WC		121	-	-
01_Plot J2_Unit J2_FF Landing		127	-	-
01_Plot J2_Unit J2_FF Lobby		127	-	-
01_Plot J2_Unit J2_FF Male WC		121	-	-
01_Plot J2_Unit J2_FF Office		122	-	-
01_Plot J2_Unit J2_FF Office Tea		122	-	-
01_Plot J2_Unit J2_FF Stairs		127	-	-
01_Plot J2_Unit J2_FF Stairs		133	-	-
01_Plot J2_Unit J2_FF Store		95	-	-
01_Plot J2_Unit J2_FF Store		95	-	-
01_Plot J2_Unit J2_FF WC		113	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Plot J2_Unit J2_GF Lobby	YES (+69%)	NO
00_Plot J2_Unit J2_GF Stairs	N/A	N/A
00_Plot J2_Unit J2_Warehouse	YES (+49.1%)	NO
01_Plot J2_Unit J2_FF Landing	NO (-10.8%)	NO
01_Plot J2_Unit J2_FF Lobby	N/A	N/A
01_Plot J2_Unit J2_FF Office	NO (-62.8%)	NO
01_Plot J2_Unit J2_FF Office Tea	NO (-78.4%)	NO
01_Plot J2_Unit J2_FF Stairs	N/A	N/A
01_Plot J2_Unit J2_FF Store	N/A	N/A
01_Plot J2_Unit J2_FF Store	N/A	N/A

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Floor area [m ²]	8134.3	8134.3
External area [m ²]	19329.4	19329.4
Weather	MAN	MAN
Infiltration [m ³ /hm ² @ 50Pa]	2	5
Average conductance [W/K]	4317.87	5358.76
Average U-value [W/m ² K]	0.22	0.28
Alpha value* [%]	25.11	10

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area Building Type

	Retail/Financial and Professional Services
	Restaurants and Cafes/Drinking Establishments/Takeaways
	Offices and Workshop Businesses
9	General Industrial and Special Industrial Groups
91	Storage or Distribution
	Hotels
	Residential Institutions: Hospitals and Care Homes
	Residential Institutions: Residential Schools
	Residential Institutions: Universities and Colleges
	Secure Residential Institutions
	Residential Spaces
	Non-residential Institutions: Community/Day Centre
	Non-residential Institutions: Libraries, Museums, and Galleries
	Non-residential Institutions: Education
	Non-residential Institutions: Primary Health Care Building
	Non-residential Institutions: Crown and County Courts
	General Assembly and Leisure, Night Clubs, and Theatres
	Others: Passenger Terminals
	Others: Emergency Services
	Others: Miscellaneous 24hr Activities
	Others: Car Parks 24 hrs
	Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	8.69	12.3
Cooling	0.33	0.13
Auxiliary	0.66	1
Lighting	7.21	4.04
Hot water	4.21	3.92
Equipment*	30.78	30.78
TOTAL **	21.11	21.4

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	8.75	4.48
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>8.75</i>	<i>4.48</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	78.22	121.52
Primary energy [kWh _{PE} /m ²]	19.5	25.5
Total emissions [kg/m ²]	1.98	2.52

HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Unflued forced-convection air heaters, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity										
Actual	71.6	0	8	0	0	2.5	0	2.5	0	
Notional	123.2	0	12.4	0	0	2.75	0	----	----	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	66.1	59.9	4.6	3.6	8	4	4.65	4.41	7.17	
Notional	56.8	14.6	5.7	0.9	21.1	2.78	4.63	----	----	
[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity										
Actual	289.6	0	100.5	0	1.8	0.8	0	1	0	
Notional	241.6	0	47.6	0	2.2	1.41	0	----	----	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	132.5	107.4	9.1	6.5	10	4.04	4.61	4.41	7.17	
Notional	114.4	22	11.4	1.3	24.6	2.78	4.63	----	----	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	40.4	71.5	2.7	4.3	8.1	4.08	4.57	4.41	7.17	
Notional	45.1	33.9	4.5	2	9.3	2.78	4.63	----	----	
[ST] Split or multi-split system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	159.4	98.3	10.8	5.4	10.1	4.11	5.09	4.41	7.17	
Notional	194.4	14.8	19.4	0.9	11.7	2.78	4.63	----	----	
[ST] No Heating or Cooling										
Actual	0	0	0	0	0	0	0	0	0	
Notional	0	0	0	0	0	0	0	----	----	

Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type