



MINI · SOIL · SURVEYS

MINI SOIL SURVEYS (NORTHERN) LTD. 12 BEECH WALK, LEIGH, LANCS. WN7 3LH

Tel: (01942) 269769
mssnorth@btinternet.com



KEY PLAN

SITE: DRAKE STREET ROCHDALE

Not to Scale : diagrammatic only: all dimensions are in metres

(BH. = Borehole TP. = Trial Pit)

MINI • SOIL • SURVEYS

MINI SOIL SURVEYS (NORTHERN) LTD.
12 Beech Walk, Leigh, Lancs. WN7 3LH



Tel: (01942) 269769
mssnorth@btinternet.com

0.00

0.00

Vegetation over dark brown ashy
sand and topsoil with bricks,
concrete fragments, gravel and
cinder.

Vegetation over dark brown ashy
sand with bricks, concrete fragments,
gravel and cinder.

1000

1000

Disturbed sample 0.2 - 0.8m

Disturbed sample 0.2 - 0.8m

TRIAL PIT 1

TRIAL PIT 2

TRIAL PITS

SITE: DRAKE STREET ROCHDALE

MINI ■ SOIL ■ SURVEYS



MINI SOIL SURVEYS NORTHERN LTD.
12 Beech Walk Leigh Lancs. WN7 3LH

Site:- DRAKE STREET ROCHDALE

Job No. NTH 2481

Date:- 26/6/19 **BH No.1**

Description	Depth	Leg	Test/ Depth	Value
Vegetation over brown sandy ashy brick and concrete rubble with some mixed gravel. MADE GROUND,			0.3 DS	
Loose brown occasionally dark brown fine to medium SAND. Possible made ground.	0.70		1.0 DS 1.2 SPT N = 8	
Loose becoming medium dense fine to medium SAND. Becoming gravelly at depth. Rare black coal fragments below 2.6m.	1.80		2.0 DS 2.4 SPT N = 9 3.6 SPT N = 13 4.8 SPT N = 16 6.0 SPT N = 30	
	6.40			

SPT @ 1.2m 1/2/2,2,2,2 @ 2.4m 1/2/2,3,2,2 @ 3.6m 3/3/3,3,3,4 @ 4.8m 3/4/3,4,4,5
@ 6.0m 6/7/7,8,7,8
Water encountered and standing on completion at 2.7m.

Key: SPT (standard penetration test). SV (shear vane). DS (disturbed sample). U38 (38mm undisturbed sample).

MINI ■ SOIL ■ SURVEYS



01942 269769

mssnorth@btinternet.com

MINI SOIL SURVEYS NORTHERN LTD.

12 Beech Walk Leigh Lancs. WN7 3LH

Site:- DRAKE STREET ROCHDALE

Job No. NTH 2481

Date:- 26/6/19

BH No.2

Description	Depth	Leg	Test/ Depth	Value
Vegetation over dark brown sand with topsoil, mixed gravel and many brick and concrete fragments. MADE GROUND. Brick aggregate concrete 3.5- 3.9m. Possible cellar floor.			0.3 DS	
			1.0 DS	
			1.2 SPT N = 12	
			2.4 SPT N = 12	
			3.6 SPT N = 46	
Medium dense dark grey/brown ashy sand with some brick fragments. MADE GROUND.	3.90			
Loose becoming medium dense brown fine to medium SAND with rare mixed gravel.	4.30		4.8 SPT N = 18	
			6.0 SPT N = 24	
	7.00			

SPT @ 1.2m 4/6/4,3,3,2 @ 2.4m 3/2/4,3,2,3 @ 3.6m 4/5/4,9,15,18 @ 4.8m 4/4/4,5,4,5

@ 6.0m 5/6/6,5,6,7

Water encountered and standing on completion at 3.9m.

Key: SPT (standard penetration test). SV (shear vane). DS (disturbed sample). U38 (38mm undisturbed sample).

MINI ■ SOIL ■ SURVEYS



01942 269769
mssnorth@btinternet.com

MINI SOIL SURVEYS NORTHERN LTD.

12 Beech Walk Leigh Lancs. WN7 3LH

Site:- DRAKE STREET ROCHDALE

Job No. NTH 2481

Date:- 26/6/19

BH No.3

Description	Depth	Leg	Test/ Depth	Value
Very dense vegetation over very loose becoming loose dark brown sand with topsoil, brick and concrete rubble, cinder, sandstone fragments and some roof slate fragments. MADE GROUND.			0.2 DS	
			1.2 SPT N = 4	
			1.8 SPT N = 10	
			2.0 DS	
Medium dense wet light brown/brown fine to medium SAND.	2.10		2.4 SPT N = 14	
			3.6 SPT N = 18	
			4.8 SPT N = 19	
			6.0 SPT N = 24	
	7.00			

SPT @ 1.2m 1/0/1,1,1,1 @ 1.8m 1/4/3,2,2,3 @ 2.4m 3/3/3,4,3,4 @ 3.6m 4/5/4,5,4,5
@ 4.8m 4/4/4,4,5,6 @ 6.0m 6/5/6,6,6,6
Water encountered and standing on completion at 2.1m.

Key: SPT (standard penetration test). SV (shear vane). DS (disturbed sample). U38 (38mm undisturbed sample).

MINI ■ SOIL ■ SURVEYS



01942 269769

mssnorth@btinternet.com

MINI SOIL SURVEYS NORTHERN LTD.

12 Beech Walk Leigh Lancs. WN7 3LH

Site:- DRAKE STREET ROCHDALE

Job No. NTH 2481

Date:- 26/6/19

BH No.4

Description	Depth	Leg	Test/ Depth	Value
Very dense vegetation over loose occasionally very loose dark brown sand, ash and brick rubble with sandstone, concrete, cinder, gravel and some glass fragments. MADE GROUND.			0.2 DS	
			1.0 DS	
			1.2 SPT N = 5	
			1.8 SPT N = 8	
			2.4 SPT N = 9	
Medium dense wet light brown/brown fine to medium SAND.	3.30		3.5 DS	
			3.6 SPT N = 16	
			4.8 SPT N = 28	
			5.4 SPT N = 30	
	6.00			

SPT @ 1.2m 1/3/2,1,1,1 @ 1.8m 1/0/1,5,1,1 @ 2.4m 2/1/3,3,2,1 @ 3.6m 3/4/4,4,4,4
@ 4.8m 7/6/7,7,7,7 @ 5.4m 7/8/7,8,7,8

Water encountered and standing on completion at 3.3m.

Key: SPT (standard penetration test). SV (shear vane). DS (disturbed sample). U38 (38mm undisturbed sample).