

Date: 25/07/2023

Address: 17 Prospect Place, OL10 4JQ

Culvert Investigations:

WMD attended site on the request to investigate where a culvert ran at prospect place.

Reason for the survey was to establish if the culvert ran close to a site where building works will potentially be taking place.

Engineer surveyed the drain and found that from the point of discharge into Millers Brook, the culvert ran in a straight line upstream for as far as we could survey which was approx. 50m.

The culvert itself was in good condition and doesn't run close to the proposed site, it runs in a straight line and is approx. 16m away as it passes the site.

There was an RBC Drainage high risk flood sites programme carried out in 2016/17 on Millers Brook – I would like to think there would be information available to what works were carried out and to where they installed the new culvert but unsure where this information would be obtained – possibly from the local council ?

Photos Below:





