

T J Booth Associates		Page 1
104 Yorkshire St Rochdale Lancashire OL16 1JY	SW attenuation jamil akhtar 806-810 manchester rd	
Date jul 2023 File CALC-T~1.SRC	Designed By ds Checked By	
Micro Drainage	Source Control W.10.4	

Summary of Results for 30 year Return Period (+40%)

Storm Duration (mins)	Maximum Control (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m ³)	Status
15 Summer	3.8	3.8	136.8342	0.2842	2.2	O K
30 Summer	3.9	3.9	136.8553	0.3052	2.3	O K
60 Summer	3.7	3.7	136.8282	0.2782	2.1	O K
120 Summer	3.3	3.3	136.7523	0.2022	1.5	O K
180 Summer	2.9	2.9	136.6927	0.1428	1.1	O K
240 Summer	2.6	2.6	136.6508	0.1008	0.8	O K
360 Summer	2.2	2.2	136.5977	0.0478	0.4	O K
480 Summer	1.9	1.9	136.5677	0.0178	0.1	O K
600 Summer	1.7	1.7	136.5513	0.0013	0.0	O K
720 Summer	1.5	1.5	136.5500	0.0000	0.0	O K
960 Summer	1.2	1.2	136.5500	0.0000	0.0	O K
1440 Summer	0.9	0.9	136.5500	0.0000	0.0	O K
2160 Summer	0.7	0.7	136.5500	0.0000	0.0	O K
2880 Summer	0.6	0.6	136.5500	0.0000	0.0	O K
4320 Summer	0.4	0.4	136.5500	0.0000	0.0	O K
5760 Summer	0.3	0.3	136.5500	0.0000	0.0	O K
7200 Summer	0.3	0.3	136.5500	0.0000	0.0	O K
8640 Summer	0.2	0.2	136.5500	0.0000	0.0	O K
10080 Summer	0.2	0.2	136.5500	0.0000	0.0	O K
15 Winter	4.0	4.0	136.8757	0.3257	2.5	O K
30 Winter	4.0	4.0	136.8858	0.3357	2.6	O K
60 Winter	3.7	3.7	136.8293	0.2792	2.1	O K
120 Winter	3.1	3.1	136.7182	0.1682	1.3	O K
180 Winter	2.6	2.6	136.6463	0.0963	0.7	O K
240 Winter	2.2	2.2	136.6022	0.0523	0.4	O K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
15 Summer	68.99	13
30 Summer	47.08	21
60 Summer	30.81	38
120 Summer	19.53	70
180 Summer	14.75	100
240 Summer	12.05	130
360 Summer	9.05	188
480 Summer	7.38	248
600 Summer	6.29	306
720 Summer	5.52	0
960 Summer	4.49	0
1440 Summer	3.35	0
2160 Summer	2.49	0
2880 Summer	2.02	0
4320 Summer	1.50	0
5760 Summer	1.21	0
7200 Summer	1.03	0
8640 Summer	0.90	0
10080 Summer	0.81	0
15 Winter	68.99	13
30 Winter	47.08	22
60 Winter	30.81	40
120 Winter	19.53	72
180 Winter	14.75	102
240 Winter	12.05	132

T J Booth Associates		Page 2
104 Yorkshire St Rochdale Lancashire OL16 1JY	SW attenuation jamil akhtar 806-810 manchester rd	
Date jul 2023 File CALC-T~1.SRC	Designed By ds Checked By	
Micro Drainage		Source Control W.10.4

Summary of Results for 30 year Return Period (+40%)

Storm Duration (mins)	Maximum Control (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m ³)	Status
360 Winter	1.8	1.8	136.5553	0.0053	0.0	O K
480 Winter	1.5	1.5	136.5500	0.0000	0.0	O K
600 Winter	1.2	1.2	136.5500	0.0000	0.0	O K
720 Winter	1.1	1.1	136.5500	0.0000	0.0	O K
960 Winter	0.9	0.9	136.5500	0.0000	0.0	O K
1440 Winter	0.7	0.7	136.5500	0.0000	0.0	O K
2160 Winter	0.5	0.5	136.5500	0.0000	0.0	O K
2880 Winter	0.4	0.4	136.5500	0.0000	0.0	O K
4320 Winter	0.3	0.3	136.5500	0.0000	0.0	O K
5760 Winter	0.2	0.2	136.5500	0.0000	0.0	O K
7200 Winter	0.2	0.2	136.5500	0.0000	0.0	O K
8640 Winter	0.2	0.2	136.5500	0.0000	0.0	O K
10080 Winter	0.2	0.2	136.5500	0.0000	0.0	O K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
360 Winter	9.05	188
480 Winter	7.38	0
600 Winter	6.29	0
720 Winter	5.52	0
960 Winter	4.49	0
1440 Winter	3.35	0
2160 Winter	2.49	0
2880 Winter	2.02	0
4320 Winter	1.50	0
5760 Winter	1.21	0
7200 Winter	1.03	0
8640 Winter	0.90	0
10080 Winter	0.81	0

Rainfall Details

Region	ENG+WAL	Shortest Storm (mins)	15
Return Period (years)	30	Longest Storm (mins)	10080
M5-60 (mm)	20.000	Summer Storms	Yes
Ratio-R	0.300	Winter Storms	Yes
Cv (Summer)	0.750	Climate Change %	+40
Cv (Winter)	0.840		

Time / Area Diagram

Total Area (ha) = 0.024

Time	(mins)	Area
from:	to:	(ha)
0	4	0.024

Tank/Pond Details

Invert Level (m) 136.550 Ground Level (m) 137.750

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.00	7.6	0.50	7.6	1.00	7.6	1.50	7.6	2.00	7.6	2.50	7.6
0.10	7.6	0.60	7.6	1.10	7.6	1.60	7.6	2.10	7.6		
0.20	7.6	0.70	7.6	1.20	7.6	1.70	7.6	2.20	7.6		
0.30	7.6	0.80	7.6	1.30	7.6	1.80	7.6	2.30	7.6		
0.40	7.6	0.90	7.6	1.40	7.6	1.90	7.6	2.40	7.6		

Orifice Outflow Control

Diameter (m) 0.055 Invert Level (m) 136.450
Discharge Coefficient 0.600