




Broadfield Slopes

Stage 3 Report

Table of Contents

Cover	1
Table of Contents	2
Description	4
Images	7
Dimming values	9

Broadfield Slopes

Images	10
Calculation objects / Light Scene 1	11
Pathway ramp to top of packer spout / Light Scene 1 / Perpendicular illuminance	16
Zig zag path / Light Scene 1 / Perpendicular illuminance	17
Ramp from car park at base of slopes / Light Scene 1 / Perpendicular illuminance	18
Packer Spout Top landing below tree / Light Scene 1 / Perpendicular illuminance	19
Site plan plus slope to Church / Light Scene 1 / Perpendicular illuminance	20
Pathway ramp to top of packer spout / Light scene 2 / Perpendicular illuminance	21
Zig zag path / Light scene 2 / Perpendicular illuminance	22
Ramp from car park at base of slopes / Light scene 2 / Perpendicular illuminance	23
Site plan plus slope to Church / Light scene 2 / Perpendicular illuminance	24

Broadfield Slopes

Outdoor space 3

Packer Spout lower walkway / Light Scene 1 / Perpendicular illuminance (adaptive)	25
---	----

Broadfield Slopes

Outdoor space 4

Packer Spout middle walkway / Light Scene 1 / Perpendicular illuminance (adaptive)	26
--	----

Broadfield Slopes

Outdoor space 5


Packer Spout walkway in front of Mercat Cross / Light Scene 1 / Perpendicular illuminance (adaptive)	27
--	----

Table of Contents

Broadfield Slopes

Outdoor space 6

Packer Spout rear walkway / Light Scene 1 / Perpendicular illuminance (adaptive) 28



Description

Design strategy

The external lighting strategy is as follows:

- Pathways through the landscape to be illuminated via 4m column mounted lanterns with asymmetric column top luminaire with no upwards light spill to 5 lux average.
- Photocell/ astronomic timeclock to switch lighting on at dusk and off at Dawn or timings to be determined through liaison with Ecologist/ Planners.
- Column mounted lanterns can be dimmed up to provide 20 lux average on walkways by Environmental Management or First Response via CMS.
- Walkways and steps within the Packer Spout area to be illuminated via re-instating historic obelisk mounted lanterns supplemented by lighting recessed or surface mounted to walls. Close liaison required with historic lantern manufacturer to ensure light spill is minimised whilst keeping aesthetic design of historic lantern intact. 30 lux average, 15 lux min on stairs.
- Market cross to be illuminated via a spotlight concealed within a new replacement lantern located on top of existing stone obelisk

Control

The exterior lighting is to be operated from a lighting controls system. The lighting control system will operate with an astronomic clock scheduled to function from dusk to dawn or within any stipulated curfews by the local planning authority. With

lighting control automation, the exterior lighting scheme only operates as and when required so the lighting can be dimmed/off outside of core hours. This can be adjusted when occupancy of the space and required light levels are better understood.

Design Illuminance Levels

The lighting levels for the external areas have been informed by the following guidance:

- ILP Guidance Note 01/21 – The reduction of obtrusive light
- ILP Guidance Note 08/18 – Bats and artificial Lighting
- CIBSE Lighting Guide 6 – The exterior environment
- BS 8300-2/2018 – Design of an accessible and inclusive built environment
- Building regulations L2A
- Secured by Design – Lighting against crime

After liaison with Rochdale Borough Council's Environmental Management department, it was advised that light levels across Broadfield Slopes should be higher than advised in BS 8300-2/2018 – Design of an accessible and inclusive built environment, due to on-going problems with anti-social behaviour and the need for maintenance. After further consultation with "Secured by Design, Lighting Against Crime – A guide for crime reduction professionals" with the council representative, it was decided to use the classification of Broadfield Slopes as a Public Space with pedestrian only traffic resulting in a light level of 20 lux on the pathways when required.

Light levels across the site are:

- Pedestrian pathways – 5 lx ave 0.25 Uo, dimming up to 20 lx ave 0.24 Uo for Environmental Management purposes.
- Steps – 30 lx ave, min 15
- Ramps – 30 lx ave

In the following pages light levels across the site are presented. The pathways through the landscape are notated as:

1. Pathway ramp to top of Packer Spout

This is an accessible ramp which leads from the carpark to the rear of the Town Hall up to the Packer Spout water feature. 2 dimming values are shown for this path.

In scene 1 levels are ave 20 lux with a slightly low uniformity. The lower light levels are at the carpark end of the ramp and with the contribution of light spill from the carpark, levels at this end of the ramp will be increased resulting in a higher uniformity.

In scene 2 light levels are dimmed down to ave 5 lux, again, with a slightly low uniformity. It is assumed that spill light from the car park will illuminate this path towards the car park end and increase the overall uniformity of the path.

2. Zig zag path

This path is not accessible for wheelchair users as it includes steps at both ends.

In scene 1 levels are ave 20 lux with a uniformity >0.25.

In scene 2 levels are ave 5 lux with a uniformity >0.25.

Lantern Heights:

Lanterns to the packer spout are to be replicas of the original and dimensions to be determined as a result of research and liaison


with manufacturer. Height of obelisk is 1500mm above the height of wall and lantern approx. 500mm in height. No tilt will be required for this lantern.

The column mounted fittings to the general pathways will be mounted on top of 4m height columns, the height to the underside of the light emitting surface is approx 650mm above the top of the column, so overall height to light emitting surface is 4650mm. There will be no tilt required for this lantern.



Images

Packer Steps 1

View to Mercat Cross from entrance to Packer Steps



Broadfield Slopes (132)




Packer Steps 4

The Mercat Cross



Images

Broadfield Slopes (130)



Packer Steps 6

View back towards Rochdale Town Hall




Dimming values

Control group	CG 1	CG 2	CG 3	CG 4
Light Scene 1	61	100	100	100
Light scene 2	15	100	100	100


Dimming values [%]

Images



Broadfield Slopes (Light Scene 1)

Calculation objects



Broadfield Slopes (Light Scene 1)

Calculation objects

Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Packer Spout middle walkway Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	59.7 lx (≥ 5.00 lx) ✓	40.9 lx	89.6 lx	0.69 (≥ 0.25) ✓	0.46	WP1
Packer Spout walkway infront of Mercat Cross Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	56.2 lx (≥ 5.00 lx) ✓	19.4 lx	107 lx	0.35 (≥ 0.25) ✓	0.18	WP2
Packer Spout rear walkway Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	31.0 lx (≥ 5.00 lx) ✓	3.81 lx	332 lx	0.12 (≥ 0.25) ✗	0.011	WP3
Packer Spout lower walkway Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	82.3 lx (≥ 5.00 lx) ✓	30.9 lx	119 lx	0.38 (≥ 0.25) ✓	0.26	WP4

Calculation surfaces

Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Zig zag path Perpendicular illuminance Height: 0.000 m	20.3 lx	9.29 lx	33.4 lx	0.46	0.28	CG1
Ramp from car park at base of slopes Perpendicular illuminance Height: 0.000 m	31.0 lx	3.40 lx	165 lx	0.11	0.021	CG2
Pathway ramp to top of packer spout Perpendicular illuminance Height: 0.000 m	20.9 lx	4.76 lx	34.2 lx	0.23	0.14	CG3
Packer Spout Top landing below tree Perpendicular illuminance Height: 4.650 m	36.4 lx	8.66 lx	141 lx	0.24	0.061	CG4
Site plan plus slope to Church Perpendicular illuminance Height: 0.000 m	5.71 lx	0.00 lx	31.8 lx	0.00	0.00	CG5

Calculation points

Broadfield Slopes (Light Scene 1)

Calculation objects

Properties	Calculated	Index
Packer Spout steps Horizontal illuminance Height: 0.151 m	39.9 lx	CP1
Packer Spout steps Horizontal illuminance Height: 0.151 m	57.5 lx	CP2
Packer Spout steps Horizontal illuminance Height: 0.001 m	91.9 lx	CP3
Packer Spout steps Horizontal illuminance Height: 0.901 m	91.2 lx	CP4
Packer Spout steps Horizontal illuminance Height: 0.601 m	64.1 lx	CP5
Packer Spout steps Horizontal illuminance Height: 0.601 m	65.6 lx	CP6
Packer Spout steps Horizontal illuminance Height: 1.051 m	79.9 lx	CP7
Packer Spout steps Horizontal illuminance Height: 1.051 m	79.5 lx	CP8
Packer Spout steps Horizontal illuminance Height: 1.501 m	81.1 lx	CP9
Packer Spout steps Horizontal illuminance Height: 1.501 m	82.1 lx	CP10
Packer Spout steps Horizontal illuminance Height: 0.001 m	79.4 lx	CP11
Packer Spout steps Horizontal illuminance Height: 0.001 m	78.3 lx	CP12

Broadfield Slopes (Light Scene 1)

Calculation objects

Properties	Calculated	Index
Packer Spout steps Horizontal illuminance Height: 2.101 m	67.4 lx	CP13
Packer Spout steps Horizontal illuminance Height: 2.101 m	62.4 lx	CP14
Packer Spout steps Horizontal illuminance Height: 2.851 m	75.2 lx	CP15
Packer Spout steps Horizontal illuminance Height: 2.851 m	92.5 lx	CP16
Packer Spout steps Horizontal illuminance Height: 2.401 m	73.7 lx	CP17
Packer Spout steps Horizontal illuminance Height: 2.401 m	62.9 lx	CP18
Packer Spout steps Horizontal illuminance Height: 2.551 m	67.3 lx	CP19
Packer Spout steps Horizontal illuminance Height: 2.551 m	80.6 lx	CP20
Packer Spout steps Horizontal illuminance Height: 3.001 m	96.0 lx	CP21
Packer Spout steps Horizontal illuminance Height: 3.001 m	39.2 lx	CP22
Packer Spout steps Horizontal illuminance Height: 4.201 m	55.7 lx	CP25
Packer Spout steps Horizontal illuminance Height: 3.601 m	142 lx	CP27

Broadfield Slopes (Light Scene 1)



Calculation objects

Properties	Calculated	Index
Packer Spout steps Horizontal illuminance Height: 3.601 m	32.6 lx	CP28
Packer Spout steps Horizontal illuminance Height: 4.201 m	130 lx	CP29
Packer Spout steps Horizontal illuminance Height: 4.201 m	59.5 lx	CP30
Packer Spout steps Horizontal illuminance Height: 4.350 m	81.6 lx	CP31
Packer Spout steps Horizontal illuminance Height: 4.350 m	51.6 lx	CP32
Packer Spout steps Horizontal illuminance Height: 4.500 m	51.5 lx	CP33
Packer Spout steps Horizontal illuminance Height: 4.500 m	82.7 lx	CP34
Packer Spout steps Horizontal illuminance Height: 4.650 m	43.5 lx	CP35
Packer Spout steps Horizontal illuminance Height: 4.650 m	25.8 lx	CP36
Packer Spout steps Horizontal illuminance Height: 3.750 m	84.9 lx	CP37
Packer Spout steps Horizontal illuminance Height: 3.750 m	40.1 lx	CP38

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)

Broadfield Slopes (Light Scene 1)


Pathway ramp to top of packer spout



Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Pathway ramp to top of packer spout	20.9 lx	4.76 lx	34.2 lx	0.23	0.14	CG3
Perpendicular illuminance						
Height: 0.000 m						

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)

Broadfield Slopes (Light Scene 1)
Zig zag path




Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Zig zag path Perpendicular illuminance Height: 0.000 m	20.3 lx	9.29 lx	33.4 lx	0.46	0.28	CG1

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)

Broadfield Slopes (Light Scene 1)




Ramp from car park at base of slopes



Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Ramp from car park at base of slopes	31.0 lx	3.40 lx	165 lx	0.11	0.021	CG2
Perpendicular illuminance						
Height: 0.000 m						

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)


Broadfield Slopes (Light Scene 1)
Packer Spout Top landing below tree



Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Packer Spout Top landing below tree Perpendicular illuminance Height: 4.650 m	36.4 lx	8.66 lx	141 lx	0.24	0.061	CG4

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)




Broadfield Slopes (Light Scene 1)

Site plan plus slope to Church

Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Site plan plus slope to Church	5.71 lx	0.00 lx	31.8 lx	0.00	0.00	CG5
Perpendicular illuminance						
Height: 0.000 m						

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)


Broadfield Slopes (Light scene 2)

Pathway ramp to top of packer spout

Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Pathway ramp to top of packer spout	6.03 lx	1.68 lx	19.0 lx	0.28	0.088	CG3
Perpendicular illuminance						
Height: 0.000 m						

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)

Zig zag path




Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$U_o (g_1)$	g_2	Index
Zig zag path Perpendicular illuminance Height: 0.000 m	5.18 lx	2.30 lx	13.2 lx	0.44	0.17	CG1

22

Broadfield Slopes (Light scene 2)


Ramp from car park at base of slopes



Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Ramp from car park at base of slopes	30.8 lx	3.40 lx	165 lx	0.11	0.021	CG2
Perpendicular illuminance						
Height: 0.000 m						

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)



Broadfield Slopes (Light scene 2)

Site plan plus slope to Church

Properties	$\bar{E}$	$E_{\min}$	$E_{\max}$	$U_0 (g_1)$	g_2	Index
Site plan plus slope to Church	2.02 lx	0.00 lx	27.1 lx	0.00	0.00	CG5
Perpendicular illuminance						
Height: 0.000 m						

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)

Outdoor space 3 (Light Scene 1)
Packer Spout lower walkway



Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Packer Spout lower walkway Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	82.3 lx (≥ 5.00 lx) ✓	30.9 lx	119 lx	0.38 (≥ 0.25) ✓	0.26	WP4

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)

Outdoor space 4 (Light Scene 1)
Packer Spout middle walkway



Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)



Outdoor space 5 (Light Scene 1)
Packer Spout walkway infront of Mercat Cross



Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Packer Spout walkway infront of Mercat Cross Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	56.2 lx (≥ 5.00 lx) ✓	19.4 lx	107 lx	0.35 (≥ 0.25) ✓	0.18	WP2

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)

Outdoor space 6 (Light Scene 1)
Packer Spout rear walkway



Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Packer Spout rear walkway Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	31.0 lx (≥ 5.00 lx) ✓	3.81 lx	332 lx	0.12 (≥ 0.25) ✗	0.011	WP3

Utilisation profile: General circulation areas at outdoor workplaces (5.1.1 Walkways exclusively for pedestrians)