
OWL ESTATES

KITCHEN ODOUR ASSESSMENT

41 YORK STREET, HEYWOOD OL10 4HD

Client: Owl Estates

Report Ref: P7636-R1-V1

Issue Date: 21st August 2024

Document Status: Version 1



DATE ISSUED: 21st AUGUST 2024

REPORT REFERENCE: P7636-R1-V1

OWL ESTATES

41 YORK STREET, HEYWOOD OL10 4HD

KITCHEN ODOUR ASSESSMENT

REPORT VERSION CONTROL:

Document Reference	Date	Report Prepared by	Report Checked by	Report Authorised by
P7636-R1-V1	21/08/2024	Maria Alarcon MSc, BSc, AMIAQM, AMIEEnvSc	Malcolm W Pouder BSc (Hons) PGDip CEnv MIEEnvSc MIAQM AFOH	Malcolm W Pouder BSc (Hons) PGDip CEnv MIEEnvSc MIAQM AFOH
				

This report has been prepared by NoiseAir Limited with all reasonable skill, care and diligence, within the terms of the contract with the client. The report is confidential to the Client and NoiseAir Limited accept no responsibility of whatever nature to third parties to whom this report may be made known.

No part of this document may be reproduced without the prior written approval of NoiseAir Limited.

CONTENTS

1	INTRODUCTION	4
2	ODOUR BACKGROUND	6
3	METHODOLOGY	9
4	ASSESSMENT	11
5	CONCLUSION	13

FIGURES

FIGURE 1	SITE LOCATION	4
FIGURE 2	EXTRACTION SYETM ON WEST ELEVATION	5

APPENDICES

APPENDIX A	- REPORT LIMITATIONS
------------	----------------------

1 INTRODUCTION

- 1.1.1 NoiseAir Limited was commissioned to undertake a Kitchen Odour Assessment (KOA) in support of a planning application for an Indian restaurant at 41 York Street, Heywood OL10 4HD. The proposal included the installation of a new kitchen extraction system.
- 1.1.2 General limitations of this report are outlined in **Appendix A**.
- 1.1.3 The Proposed Development has the potential to cause odour impacts as a result of emissions from cooking processes occurring within the new kitchen. As such, a KOA was undertaken in order to evaluate potential effects as a result of the proposals and identify the necessary mitigation measures to prevent adverse impacts.

1.2 Site Location and Context

- 1.2.1 The Proposed Development is located within Rochdale Metropolitan Borough Council at 41 York Street, Heywood OL10 4HD, at approximate National Grid Reference (NGR): 385730, 410810.
- 1.2.2 **Figure 1** shows the location of the Site.



Figure 1 Site Location

- 1.2.3 The Site is bounded by York Street to the south, John Street to the east, Adelaide Street to the north and Queen's Park Road to the west. It is located within an area characterised by a mix of residential properties, retail establishments, and other business uses. Given its location, sensitive receptors are present within a 20 metres radius of the Site.
- 1.2.4 The restaurant specialises in Indian cuisine and has a seating capacity of 100 covers.
- 1.2.5 The extraction system is located on the west side of the building as shown in **Figure 2**. The discharge point is situated on the first floor into a courtyard/parking space fronting John Street.



Figure 2 Extraction Syetm on West Elevation

- 1.2.6 At the time of writing, it is known that this scheme includes some type of filters; however, specifics are not known.

2 ODOUR BACKGROUND

2.1 Odour Definition

2.1.1 The Institute of Air Quality Management (IAQM) guidance¹ defines odour as:

"[...]the human olfactory response (perception followed by psychological appraisal) to one, or more often a complex mixture of, chemical species in the air."

2.1.2 The stated definition is considered to be relevant in the context of this assessment.

2.2 Odour Impacts

2.2.1 The magnitude of odour impacts depends on a number of factors and the potential for complaints varies due to the subjective nature of odour perception. The **FIDOL** acronym is a useful reminder of the factors that will determine the degree of odour pollution. These are described by the IAQM as follows:

- **Frequency** - how often an individual is exposed to odour;
- **Intensity** - the individual's perception of the strength of odour;
- **Duration** - The overall duration that individuals are exposed to an odour over time;
- **Odour unpleasantness** - Odour unpleasantness describes the character of an odour as it relates to the 'hedonic tone' (which may be pleasant, neutral or unpleasant) at a given odour concentration/intensity. This can be measured in the laboratory as the hedonic tone, and when measured by the standard method and expressed on a standard nine-point scale it is termed the hedonic score; and,
- **Location** - the type of land use and nature of human activities in the vicinity of an odour source. Tolerance and expectation of the receptor. The 'Location' factor can be considered to encompass the receptor characteristics, receptor sensitivity, and socio-economic factors.

2.2.2 It is important to note that even infrequent emissions may cause loss of amenity if odours are perceived to be particularly intense or offensive.

2.2.3 The **FIDOL** factors can be further considered to provide the following issues in regard to the potential for an odour emission to cause a nuisance:

- The rate of emission of the compound(s);
- The duration and frequency of emissions;

¹ Guidance on the Assessment of Odour for Planning v1.1, IAQM, 2018.

-
- The time of the day that this emission occurs;
 - The prevailing meteorology;
 - The sensitivity of receptors to the emission i.e. whether the odorous compound is more likely to cause nuisance, such as the sick or elderly, who may be more sensitive;
 - The odour detection capacity of individuals to the various compound(s); and,
 - The individual perception of the odour (i.e. whether the odour is regarded as unpleasant). This is greatly subjective and may vary significantly from individual to individual. For example, some individuals may consider some odours as pleasant, such as petrol, paint and creosote.

2.3 Legislative Control

- 2.3.1 The main requirement with respect to odour control from premises not controlled under the Environmental Permitting (England and Wales) Regulations (2016) and subsequent amendments, such as the proposed school kitchen, is that provided in Section 79 of Part III of the Environmental Protection Act (1990). The Act defines nuisance as:

"Any dust, steam, smell or other effluvia arising on industrial, trade or business premises and being prejudicial to health or a nuisance."

- 2.3.2 Enforcement of the Act, in regard to nuisance, is currently under the jurisdiction of the local Environmental Health Department, whose officers are deemed to provide an independent evaluation of nuisance. If the Local Authority is satisfied that a statutory nuisance exists, or is likely to occur or happen again, it must serve an Abatement Notice under Part III of the Environmental Protection Act (1990). The only defence is to show that the process to which the nuisance has been attributed and its operation are being controlled according to best practicable means.

- 2.3.3 The legislative controls described above were considered as necessary throughout the undertaking of the assessment.

2.4 National Planning Policy

- 2.4.1 The revised National Planning Policy Framework² was published in December 2023 and sets out the Government's Planning policies for England and how these are expected to be applied.

² NPPF, Ministry of Housing, Communities and Local Government, 2023.

2.4.2 The purpose of the planning system is to contribute to the achievement of sustainable development. In order to ensure this, the NPPF recognises three overarching objectives included the following of relevance to odour:

" c) An environmental objective - to protect and enhance our natural, built and historic environment; including making effective use of land, improving biodiversity, using natural resources prudently, minimising waste and pollution, and mitigating and adapting to climate change, including moving to a low carbon economy."

2.4.3 Chapter 12 of the NPPF details objectives in relation to achieving well-designed place. It states that:

"Planning policies and decisions should ensure that developments:[...]

f) create places that are safe, inclusive and accessible and which promote health and well-being, with a high standard of amenity for existing and future users; and where crime and disorder, and the fear of crime, do not undermine the quality of life or community cohesions and resilience [...]"

2.4.4 The implications of the NPPF have been considered throughout this assessment.

3 METHODOLOGY

3.1 Introduction

3.1.1 The Proposed Development has the potential to cause odour impacts as a result of emissions from cooking processes. An assessment has therefore been undertaken in accordance with the guidance document 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems' prepared by EMAQ+ for Department for Environment, Food and Rural Affairs (DEFRA)³. This document provides an update to the 2005 guidance⁴ produced by DEFRA.

3.2 Assessment Methodology

3.2.1 The EMAQ+ and DEFRA methodology provides an approach for identifying the risk of odour impact associated with food preparation premises and defining an appropriate level of mitigation to control potential effects to an acceptable level.

3.2.2 The first stage in the process is to score the premises in accordance with the criteria outlined in **Table 1**.

Table 1: Risk Scoring Criteria			
Criteria	Score	Score	Details
Dispersion	Very poor	20	Low level discharge, discharge into courtyard or restriction on stack
	Poor	15	Not low level but below eaves, or discharge at below 10m/s
	Moderate	10	Discharging 1m above eaves at 10 - 15m/s
	Good	5	Discharging 1m above ridge at 15m/s
Proximity of receptors	Close	10	Closest sensitive receptor less than 20m from kitchen discharge
	Medium	5	Closest sensitive receptor between 20 and 100m from kitchen discharge
	Far	1	Closest sensitive receptor more than 100m from kitchen discharge
Size of kitchen	Large	5	More than 100 covers or large sized takeaway
	Medium	3	Between 30 and 100 covers or medium sized takeaway
	Small	1	Less than 30 covers or small take away
Cooking type (odour and grease loading)	Very High	10	Pub (high level of fried food), fried chicken, burgers or fish & chips, Turkish, Middle Eastern or any premises cooking with solid fuel

³ Control of Odour and Noise from Commercial Kitchen Exhaust Systems, EMAQ+, 2018.

⁴ Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems, DEFRA, 2005.

Table 1: Risk Scoring Criteria

Criteria	Score	Score	Details
	High	7	Vietnamese, Thai, Indian, Japanese, Chinese or steakhouse
	Medium	4	Cantonese, Italian, French, Pizza (gas fired)
	Low	1	Most pubs (no fried food, mainly reheating and sandwiches etc) or Tea rooms

- 3.2.3 The score obtained using the values shown in **Table 1** is subsequently used to define the associated risk and odour control requirement. The relevant criteria are summarised in **Table 2**.

Table 2: Odour Control Requirement

Significance Score	Impact Risk	Odour Control Requirement
Less than 20	Low to Medium	Low level odour control
20 to 35	High	High level odour control
More than 35	Very high	Very high level odour control

- 3.2.4 A suitable odour control system can then be identified from the techniques summarised in the EMAQ+ and DEFRA guidance.

4 ASSESSMENT

4.1 Odour Risk

4.1.1 The odour risk associated with the Proposed Development was rated in accordance with the EMAQ+ and DEFRA methodology.

Dispersion;

4.1.2 Emissions terminates at a low level into a courtyard/ parking space on John Street (west side of the building). Therefore, based on the information in **Table 1**, the risk rating for dispersion would be described as **Very Poor**.

Proximity of receptors;

4.1.3 The closest sensitive receptors are within 20 metres of the kitchen discharge. Therefore, based on the information in **Table 1**, the risk rating for proximity of receptors would be described as **Close**.

Size of kitchen;

4.1.4 It is understood that this restaurant offers 100 covers in total. Based on the information in **Table 1**, the risk rating for the size of the kitchen would be described as **Medium**.

Cooking type (odour-grease loading);

4.1.5 The Site is an Indian restaurant; therefore, based on the information in **Table 1**, the risk rating for the cooking type would be described as **High**.

4.1.6 The results are summarised in **Table 3**.

Table 3: Odour Risk			
Criteria	Score	Score	Notes
Dispersion	Very poor	20	Low level discharge, discharge into courtyard or restriction on stack
Proximity of receptors	Close	10	Closest sensitive receptor less than 20m from kitchen discharge
Size of kitchen	Medium	3	Between 30 and 100 covers or medium sized takeaway
Cooking type (odour and grease loading)	High	7	Vietnamese, Thai, Indian, Japanese, Chinese or steakhouse

4.1.7 As shown in **Table 3**, the odour risk from the kitchen was scored as **40**. The risk was therefore classified as **Very High**, in accordance with the EMAQ+ and DEFRA criteria.

4.2 Odour Control

4.2.1 Based on the assessment results, the kitchen requires mitigation suitable for a **Very High** level of odour control.

4.2.2 A **Very High** level of odour control may include:

1. Fine filtration or electrostatic precipitation (ESP) followed by carbon filtration (carbon filters rated with 0.4 – 0.8 second residence time).
2. Fine filtration or ESP followed by carbon filtration and by counteractant/neutralising system to achieve the same level of control as carbon filters previously described.
3. Fine filtration or ESP followed by UV ozone system to achieve the same level of control as previously described.

4.2.3 It is understood that this scheme includes some level of odour control with filters. However, specific details are not currently known. In line with the guidance, odour control measures such as those proposed above should be employed to reduce any odour impact to an acceptable level at the nearest sensitive receptor locations.

4.2.4 It is recommended to replace the carbon filters (if fitted) regularly and to routinely maintain and clean the extraction system in order to minimise the potential for any odour related complaints.

4.2.5 Based on the findings of the assessment, it is considered that potential odour impacts at nearby sensitive receptors would be reduced to an acceptable level, subject to the inclusion of the recommended mitigation within the guidance, if deemed appropriate.

5 CONCLUSION

- 5.1.1 NoiseAir Limited was commissioned to undertake a KOA in support of an Indian restaurant at 41 York Street, Heywood OL10 4HD.
- 5.1.2 The Proposed Development has the potential to cause odour impacts as a result of cooking processes within the kitchen. As such, a KOA has been undertaken in order to consider potential impacts associated with the scheme and identify suitable odour control measures.
- 5.1.3 An assessment using the EMAQ+ and DEFRA methodology was undertaken in order to identify the odour risk associated with the extract system. This was based on a number of site-specific inputs.
- 5.1.4 The results of the assessment indicated the odour risk was classified as **Very High**. This prediction outlines that the Development could result in significant odour impact at nearby sensitive receptors or affect local amenity levels in the absence of mitigation. It also suggests that appropriate mitigation options are required to reduce potential effects to an acceptable level.
- 5.1.5 The specified and recommended odour abatement strategy for the Site, described in paragraph 4.2.2, is considered appropriate for the nature of the Development and is consistent with the requirements of the EMAQ+ and DEFRA guidance for kitchens with a **Very High** risk of impact. Therefore, with this mitigation in place, potential odour impacts at nearby sensitive receptors would be reduced to an acceptable level.
- 5.1.6 Based on the findings of the assessment, it is considered that odour emissions should not represent a constraint to planning consent for the Development, as long as **Very High** level odour control as outlined in the EMAQ+ and DEFRA guidance is employed at the Site.

APPENDIX A - REPORT LIMITATIONS

This Report is presented to Owl Estates and may not be used or relied on by any other person or by the client in relation to any other matters not covered specifically by the scope of this report.

Notwithstanding anything to the contrary contained in the report, NoiseAir Limited is obliged to exercise reasonable skill, care and diligence in the performance of the services required by Owl Estates and NoiseAir shall not be liable except to the extent that it has failed to exercise reasonable skill, care and diligence, and this report shall be read and construed accordingly.

This report has been prepared by NoiseAir Limited. No individual is personally liable in connection with the preparation of this report. By receiving this report and acting on it, the client or any other person accepts that no individual is personally liable whether in contract, tort, for breach of statutory duty or otherwise.

The conclusions and recommendations contained in this report are based upon information provided by others and upon the assumption that all relevant information has been provided by those parties from who it has been requested and that such information is accurate. Information obtained by NoiseAir Limited has not been independently verified by NoiseAir Limited unless otherwise stated in the report and should be treated accordingly.

The methodology adopted and the sources of information used by NoiseAir Limited in providing its services are outlined in this report. The work described in this report was undertaken during the dates given in Section 1 and Section 2 and is based upon the conditions encountered as detailed in Section 2 and the information available up to the said date. The scope of this report and the services are accordingly factually limited by these circumstances.

Where assessments of works or costs identified in this report are made, such assessments are based upon the information available at the time and where appropriate are subject to further investigations or information which may become available.

Where / if estimates and projects are made within this report, are made based on reasonable assumptions as of the date of this report, such statements however by their very nature involve risks and uncertainties that could cause actual results to differ materially from the results predicted. NoiseAir Limited specifically does not guarantee or warrant any estimates or projects contained in this report.

DISCLAIMER- This report was prepared by NoiseAir Limited. The material in it contains NoiseAir Limited best judgment in light of the information available at the time of preparation of this report. Any use which a third party makes of this report, or any reliance on, or decisions based on it are the responsibility of such third parties. NoiseAir Limited accept no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions taken based on this report.

NoiseAir Limited

Specialist acoustic and air quality engineers providing a fast, professional, cost-effective service for all types of Acoustic Consultancy services across the UK.

Over 25 years of experience in the field.

Contact us now for a free, no obligation quote or to discuss your requirements.

NOISEAIR LIMITED, THE COUNTING HOUSE, HIGH STREET,
LUTTERWORTH. LE17 4AY

TEL. 0116 272 5908

EMAIL. INFO@NOISEAIR.CO.UK

WWW.NOISEAIR.CO.UK

