

From: [Tahir Rafiq](#)
To: [Nick Brookman](#)
Cc: [Development Management](#)
Subject: 25/00607/TELE - North Manchester Golf Club
Date: 24 July 2025 10:17:14
Attachments: [image001.png](#)
[image002.png](#)
[image003.png](#)

Hi Nick,

The Environmental Protection Team have reviewed the supporting information for the installation of 30m high lattice tower, 6no antennas, 4no dishes, 1no equipment cabinet, 1no shared meter cabinets and ancillary development throughout. As there are residential dwellings in close proximity the Environmental protection team would require a noise assessment to determine the current background levels and the noise levels generated by the installation. The Environmental Protection Team would also request the construction working hours to the following:

Construction Hours

The hours of construction and demolition are restricted to 8.00am to 6.00pm Monday to Friday;
9.00am to 2.00pm on Saturday

Kind Regards

Tahir

Tahir Rafiq

Specialist Lead (Environmental/Health Protection)
Public Protection



ROCHDALE
BOROUGH COUNCIL

☎ 01706 924606

✉ tahir.rafiq@rochdale.gov.uk

Rochdale Borough Council

Floor 3, Number One Riverside

Smith Street, Rochdale, OL16 1XU

To access our services go to www.rochdale.gov.uk

For news, events and social media updates go to www.rochdale.gov.uk/newsandevents

Please consider the environment before printing this email.