

From: [David Dutton](#)
To: [Development Management](#)
Subject: Planning application 25/00866/DOC The Crimble Restaurant
Date: 03 September 2025 11:23:01

:CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Hi Nick

Thank you for consulting the GMEU.

I have restricted my response to condition 11.

Condition 11 – Tree Protection Measures

My colleague Derek Richardson would normally deal with arboricultural issues. However, this appears relatively straightforward, with the majority of the trees sufficiently distant from construction that fencing off is adequate to keep construction activities and machinery way from the root protection areas. Only one small area requires additional measures, where protective matting is proposed within the RPA.

I therefore have no objection to discharge of the prior to part of condition 11.

David Dutton

Ecologist

Planning and Transportation

Planning and Transportation

Place

[Tameside MBC](#) | [X](#) | [Facebook](#) | [Instagram](#) | [LinkedIn](#)

Dukinfield Town Hall | King Street | Dukinfield | Tameside | SK16 4LA

Tel. 0161 342 2895

Mobile. 07583961784

***This email was sent at a time & date convenient to the sender;
please do not feel under any pressure to respond immediately if
this is outside your normal working hours.***

Email Disclaimer <https://www.tameside.gov.uk/disclaimer>