


1. THIS DRAWING IS THE COPYRIGHT OF CDD BENTLEY AND MUST NOT BE REPRODUCED, COPIED OR USED WITHOUT CDD BENTLEY'S WRITTEN CONSENT.
2. THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL CDD BENTLEY DRAWINGS, SCHEDULES AND SPECIFICATIONS.
3. DO NOT SCALE FROM THIS DRAWING.
4. ALL DIMENSIONS AND LEVELS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.
5. ALL PLANT, MATERIALS AND EQUIPMENT TO BE INSTALLED STRICTLY IN ACCORDANCE WITH MANUFACTURERS' RECOMMENDATIONS.
6. ANY DISCREPANCY IS TO BE REFERRED TO CDD BENTLEY CONSULTING.
7. ALL DIMENSIONS TO BE CHECKED AND VERIFIED ON SITE PRIOR TO THE COMMENCEMENT OF WORKS.
8. ALL PART NUMBERS SHALL BE VERIFIED BY THE CONTRACTOR.
9. THIS DRAWING IS TO BE READ IN CONJUNCTION AND COORDINATION WITH ALL OTHER DESIGN TEAM PROJECT DRAWINGS, SCHEDULES AND SPECIFICATIONS.

Luminaire Schedule									
Symbol	Qty	Label	Arrangement	Description	LED	Luminaire Watts	Mounting Height	[MORFAC]	
	1	A	Single	80w LED 2700K Mini Martin 14 LED with L35 Optic column mounted	0.900	80	6	VIRBLO by Lighting Project Solutions	
	2	AK	Single	80w LED 2700K Mini Martin 14 LED with L35 Optic well mounted	0.900	80	7	VIRBLO by Lighting Project Solutions	
	2	A2	Back-Back	2x 80w LED 2700K Mini Martin 14 LED with L35 Optic column mounted on twin bracket	0.900	80	6	VIRBLO by Lighting Project Solutions	
	5	D	Single	280w LED 2700K 400K 44 LED with L35 Optic column mounted	0.900	280	8	VIRBLO by Lighting Project Solutions	
	6	FW	Single	280w LED 2700K 400K 44 LED with L35 Optic wall mounted	0.900	280	8	VIRBLO by Lighting Project Solutions	
	20	QHE	Single	8w LED 2700K Pinn Emergency Bulkhead with Pathway Optic wall mounted	0.900	7.5	2.5	Lighting Project Solutions	

Label	CalcType	Units	Avg	Max	Min	Min/Avg	Min/Max	Description
Access	Illuminance	50x	20	44	5	0.25	0.11	
Building Perimeter	Illuminance	50x	13	79	1	0.08	0.01	
Car Park	Illuminance	50x	20	69	5	0.25	0.07	
Cycle Stores	Illuminance	50x	28	38	23	0.81	0.61	
Loading Bays	Illuminance	50x	67	136	30	0.44	0.22	
Service Yard	Illuminance	50x	84	140	25	0.46	0.18	



REF A, AW, A2



REF D, FW



REF GWE

[illegible]

P02	UPDATED ARCHITECTURAL BACKGROUND	HC	TOG	RD	29-01-20
P01	PRELIMINARY ISSUE	HC	TOG	RD	16-01-20
Revision	Description	Drawn By	Engineer	Approved	Date



Cudd Bentley Consulting Ltd. Ashurst Manor Church Lane Ascot Berkshire SL5 7DD	Cudd Bentley Consulting Ltd. Regus, Central Boulevard Bythe Valley Business Park Solihull, West Midlands, B60 8AG	Cudd Bentley Consulting Ltd. 12 Devonshire Street London W1G 7AB
---	---	---

PRELIMINARY

Client

Project Site Location

BIRCH BUSINESS PARK
UNIT B

Displaying Title

PROPOSED EXTERNAL LIGHTING LAYOUT

Scale	Size	Drawn By	Engineer	Approved	Date
1:250	A0	HC	TOG	RD	16/01/25

7091-CBC-00-XX-DR-U-196005

P02