



200 Lichfield Lane
Mansfield
Nottinghamshire
NG18 4RG

T: 01623 637 119 (Planning Enquiries)

E: planningconsultation@coal.gov.uk

W: www.gov.uk/coalauthority

For the attention of: Ms C Ringwood
Rochdale Metropolitan Borough Council

[By email: development.management@rochdale.gov.uk]

20 February 2026

Dear Ms Ringwood

Re: PL/2025/1199

Erection of retirement living community comprising 49 retirement apartments (category 2 type accommodation), associated communal facilities, landscaping and car parking together with 18 retirement bungalows; Land At Bamford Mews, Off Norden Road, Bamford, OL11 5NX

Thank you for your notification of 12 February 2026 seeking the views of the Coal Authority on the above.

The Coal Authority is a non-departmental public body sponsored by the Department for Energy Security and Net Zero (DESNZ). As a statutory consultee, The Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority Response: **Material Consideration**

I have reviewed the proposals and confirm that the application site falls within the defined Development High Risk Area; therefore within the application site and surrounding area

there are coal mining features and hazards which need to be considered in relation to the determination of this planning application.

The Coal Authority records indicate that a thick coal seam outcrops at or close to the surface of the site which may have been worked in the past and historic unrecorded underground coal mining is likely to have taken place beneath the site at shallow depth. Voids and broken ground associated with such workings can pose a risk of ground instability and may give rise to the emission of mine gases. The site also lies within a Surface Coal Resource Zone.

The applicant has obtained appropriate and up-to-date coal mining information for the proposed development site. This information has been used to inform a Phase 2 Site Investigation Report (November 2024, prepared by Clancy Consulting) to accompany the planning application.

The report is able to identify that the drilling of rotary open hole boreholes to depths of at least 30m was undertaken to investigate the presence of any voids associated with historic coal mining activities.

No worked coal, broken ground, loss of flush or voids were recorded to a maximum depth of 35.00m bgl. The report author therefore considers that the area of the proposed development is not affected by shallow coal workings and no remedial works are required.

Mine Gas

It should be noted that wherever coal resources or coal mine features exist at shallow depth or at the surface, there is the potential for mine gases to exist. These risks should always be considered by the LPA. The Planning and Development Team at the Coal Authority, in its role of statutory consultee in the planning process, only comments on gas issues if our data indicates that gas emissions have been recorded on the site. However, the absence of such a comment should not be interpreted to imply that there are no gas risks present. Whether or not specific emissions have been noted by the Coal Authority, local planning authorities should seek their own technical advice on the gas hazards that may exist, and appropriate measures to be implemented, from technically competent personnel.

Sustainable Urban Drainage

It should be noted that where SUDs are proposed as part of the development scheme consideration will need to be given to the implications of this in relation to the stability and public safety risks posed by coal mining legacy. The developer should seek their own advice from a technically competent person to ensure that a proper assessment has been made of the potential interaction between hydrology, the proposed drainage system and ground stability, including the implications this may have for any mine workings which may be present beneath the site.

The Coal Authority Recommendation to the LPA

The Coal Authority considers that the content and conclusions of the Phase 2 Site Investigation Report are sufficient for the purposes of the planning system and meets the requirements of NPPF in demonstrating that the application site is, or can be made, safe and stable for the proposed development. The Coal Authority therefore has **no objection** to the proposed development. However, further more detailed considerations of ground conditions and/or foundation design may be required as part of any subsequent building regulations application.

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Ashley Langrick

Ashley Langrick BA (HONS) Dip TRP MRTPI
Planning and Development Manager (Corporate Projects)

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.

In formulating this response The Coal Authority has taken full account of the professional conclusions reached by the competent person who has prepared the Coal Mining Risk Assessment or other similar report. In the event that any future claim for liability arises in relation to this development The Coal Authority will take full account of the views, conclusions and mitigation previously expressed by the professional advisers for this development in relation to ground conditions and the acceptability of development.