



Azymuth Acoustics UK

Professional Acoustic Services

Noise Impact Assessment

Ref: AA0521 Rev A

28no. Residential Units

Queens Drive

Rochdale,

OL11 2NP

On behalf of

MSV Housing

7th Trafford House,

Chester Road,

Old Trafford,

Manchester,

M32 0RS



Azymuth Acoustics UK

Viridor House

No.3 Bolholt Terrace

Bury/Gtr Manchester

BL8 1PP

Tel: +44 (0)161-762 1055

Fax: +44 (0)161-761 1094

Matthew@acousticsuk.com

www.acousticsuk.com



Document Status – Final

Ref: AA0521	Signature:	Name:	Date:
Produced by:		Ollie Platts, BSc (Hons), DIPL, AMIOA	26/11/24
Revised by:		Dominic McCann, BEng (Hons), MIOA, Director	11/03/26
Approved by:		Matthew Gibson, BEng (Hons), CEng, CEnv, Director	11/03/26

Disclaimer

This report has been prepared by Azymuth Acoustics UK with all reasonable skill, care and diligence within the terms of the Contract with the client, incorporating our Standard Terms and Conditions of Business and taking into account the resources devoted to it by agreement with the Client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above.

This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own discretion and risk.



Contents

1.0	Introduction	4
2.0	Baseline Noise Survey	5
2.1	Measurement Procedures	5
2.2	Summary of Measurements	6
2.3	Description of Noise Climate	6
3.0	Assessment Criteria	7
3.1	ProPG: Planning and Noise - May 2017	7
3.2	National Planning Policy Framework (NPPF) 2023	7
3.3	British Standard 8233: 2014	7
3.4	World Health Organisation Environmental Noise Guidelines (ENG) 2018	8
3.5	British Standard 4142:2014+A1:2019	8
3.6	IOA Guide to Noise Requirements of Approved Document O 2022	9
3.7	Acoustics Ventilation and Overheating Residential Design Guide 2020	9
3.8	Recommended Noise Assessment Criteria	9
4.0	Assessment of Results	10
4.1	Assessment of Noise Risk	10
4.2	SoundPLAN Model	11
4.3	Assessment of Noise in External Amenity Spaces	13
5.0	Recommendations for Noise Mitigation.....	13
5.1	Recommended Glazing Specification	13
5.2	Recommended Ventilation Specification	14
5.3	Mitigation Specifications.....	14
5.4	Other Elements of Building Envelope.....	15
6.0	Summary.....	16
	Appendix A – Glossary of Acoustic Terms.....	17
	Appendix B – Noise Survey Data	18

2.0 Baseline Noise Survey

2.1 Measurement Procedures

The instrumentation used for the NIA consisted of a SvanTek 971 type 1 precision sound level meter. The equipment was calibrated before and after measurements. The sound level meter measured A-weighted (fast response) noise levels as well as octave bands noise levels for all measurement record.

Daytime noise level measurements were undertaken between 12:52hrs and 16:09hrs on Tuesday 26th November 2024. The night-time measurements were undertaken between 23:00hrs on Monday 2nd December and 00:19hrs on Tuesday 3rd December 2024.

The noise measurements were undertaken using the sound level meter at the positions shown in Figure 2 below:

- Position 1: Existing carpark entrance, northeast of site boundary (~1m from roadside)
- Position 2: Site footpath entrance, central of site boundary (~1m from roadside)
- Position 3: Q-Gardens, northwest of site boundary (~1m from roadside)



Figure 2 – Noise measurement positions



2.2 Summary of Measurements

2.2.1 Noise Survey

The following table summarises the results of the noise measurements undertaken at the proposed site in terms of the average daytime and night-time noise levels.

Location	Period	L _{AFmax}	L _{Aeq}	L _{A10}	L _{A50}	L _{A90}
1) Existing carpark	Day	79.1	65.0	68.5	60.2	56.8
1) Existing carpark	Night	74.4	57.7	57.5	53.1	49.4
2) Site footpath	Day	80.7	66.2	68.9	62.5	60.0
2) Site footpath	Night	71.4	56.1	57.3	50.8	44.2
3) Q-Gardens	Day	80.3	68.2	71.3	66.0	61.3
3) Q-Gardens	Night	76.5	58.1	60.1	50.2	43.6

Table 1 – Summary of noise measurements

Azymuth assumes that all noise levels measured on-site during the baseline noise survey are typical of the site.

Full results of the noise levels recorded during the course of the survey are included in Appendix B of this report.

2.2.2 Assessment of Night-time L_{Amax} Data

Azymuth has carried out an assessment of the available night-time L_{Amax} noise level data for measurement position 3 (referenced to ~1m from the roadside). The highest measured L_{Amax} value was 79.2dB and the duration of the night-time survey at this position was exactly 25 minutes, hence it is estimated that the 10th highest L_{Amax} value over the entire 8hr night-time period is likely to be around 79-82dB.

2.3 Description of Noise Climate

The main sources of noise affecting the site are road traffic from Queens Drive, running along the northern boundary of the site, as well as the A664 main road, which runs parallel to Queens Drive set back 3m to 8m.

The weather throughout the assessment was mild, mostly dry with occasional drizzle and maximum wind speeds of 10mph.

3.0 Assessment Criteria

In order to assess the extent of any measures required in order to comply with suitable conditions relating to potential noise sources, Azymuth Acoustics UK has reviewed various guidance documents and standards, these include:

- ProPG: Professional Practice Guidance on Planning and Noise (New residential development)
- National Planning Policy Framework (NPPF 2023)
- British Standard 8233:2014
- World Health Organisation Guidelines on Community Noise
- British Standard 4142:2014+A1:2019
- IOA Guide to Noise Requirements of Approved Document O 2022
- Acoustics Ventilation and Overheating Residential Design Guide 2020

3.1 ProPG: Planning and Noise - May 2017

This Professional Practice Guidance on Planning and Noise (ProPG) has been produced to provide practitioners with guidance on a recommended approach to the management of noise within the planning system in England. The National Planning Policy Framework (NPPF) encourages improved standards of design. The CIEH, IOA and the ANC have worked together to produce this guidance which encourages better acoustic design for new residential development and aims to protect people from the harmful effects of noise.

The Professional Practice Guidance on Planning and Noise States 'The recommended approach is intended to give the developer, noise practitioner, and decision maker an early indication of the likely initial suitability of the site for new residential development from a noise perspective and the extent of acoustic issues that would be faced'. It is important that acoustic design is reviewed at an early stage of the development process.

3.2 National Planning Policy Framework (NPPF) 2023

The NPPF provides guidance to local authorities taking into account noise in making planning decisions. Paragraph 185 of the National Planning Policy Framework (NPPF) states that planning policies and decisions should aim to:

- Mitigate and reduce to a minimum to a minimum potential adverse impacts resulting from new development – and avoid noise giving rise to significant adverse impacts on health and quality of life,
- Identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason;

The NPPF states that the planning system should distinguish between the hierarchy of international, national and locally designated sites; allocate land with the least environmental or amenity value, where consistent with other policies in this Framework. In addition, NPPF states that the planning system should 'prevent both new and existing development from contributing to or being put at unacceptable risk from, or being adversely affected by unacceptable levels of soil, air, water or noise pollution or land instability'.

3.3 British Standard 8233: 2014

BS 8233 provides a code of practice for the sound insulation of a variety of building types affected by general environmental noise. It provides recommendations for control of noise in and around buildings and suggests appropriate internal ambient noise level criteria / limits for a variety of different situations including residential properties.



The following table summarises the noise limits suggested by BS 8233 applying to residential properties:

Activity	Room	Good Design Range $L_{Aeq,T}$ dB	
		07:00-23:00hrs	23:00-07:00hrs
Resting	Living Room	35	-
Dining	Dining Room / Area	40	-
Sleeping (daytime resting)	Bedroom (at night)	35	30

Table 2 – Noise Limits for Residential Properties Suggested in BS 8233

BS 8233 also states that traditional external areas that are used for amenity space, such as gardens and patios, it is desirable that the external noise level does not exceed 50dB $L_{Aeq,T}$, with an upper guideline value of 55dB $L_{Aeq,T}$, which would be acceptable in noisier environments.

3.4 World Health Organisation Environmental Noise Guidelines (ENG) 2018

The main purpose of the 2018 WHO guidelines is to provide recommendations for protecting human health from exposure to environmental noise originating from the following sources: transportation (road traffic, railway and aircraft), wind turbines and leisure activities.

The guidelines set out to define recommended exposure levels for environmental noise in order to protect population health. Exposure limits are average levels defined over a period of one year, measured outdoors in free field at the most exposed façade. It should be noted that the document does not provide guideline limit values for multiple noise sources in combination.

The 2018 guidelines supersede the Community Noise Guidelines from 1999. Nevertheless, the document recommends that all CNG indoor guideline values and any values not covered by the current guidelines should remain valid. As such, the following guidance would remain appropriate:

For protection against sleep disturbance inside dwellings, night-time noise levels should not exceed 30dB L_{Aeq} for continuous noise and 45dB L_{Amax} for typical single sound events (which are exceeded 15 times or more per night – see ProPG Appendix A.12 for more details).

To protect the majority of people from being seriously annoyed during the daytime, the outdoor sound level from steady, continuous noise (interpreted as noise from all sources combined) should not exceed 55dB L_{Aeq} on balconies, terraces and in outdoor living areas.

It should be noted that exposure levels defined in ENG and CNG are for guidance purposes as relates potential adverse health impacts and should not be interpreted as absolute limits or regulations.

3.5 British Standard 4142:2014+A1:2019

“Methods for assessing and rating industrial sound” describes methods for rating and assessing sound of an industrial and/or commercial nature. The methods described in this British Standard use outdoor sound levels to assess the likely effects of sound on people who might be inside or outside a dwelling or premises used for residential purposes upon which sound is incident.

- Typically, the greater the difference between background sound and industrial/commercial noise, the greater the magnitude of the impact.

- The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.
- A difference of around +5dB is likely to be an indication of an adverse impact, depending on the context.
- A difference of around +10dB or more is likely to be an indication of a significant adverse impact, depending on the context.

BS 4142 notes that: “Adverse impacts include, but are not limited to, annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact.”

3.6 IOA Guide to Noise Requirements of Approved Document O 2022

Approved Document O ‘Overheating’ was released in December 2021 and came into effect in England on 15th June 2022. It introduces requirements for various types of residential premises to limit unwanted solar gains in summer and provide an adequate means to remove heat from the indoor environment (Requirement O1 (1)). Requirement O1(2)(a) of the regulation requires that account must be taken of the safety of an occupant, and their reasonable enjoyment of the residence. There is also a requirement (O2(b)) that mechanical cooling may only be used where sufficient heat cannot be removed from the indoor environment without it.

The guide aims to set out a method to demonstrate compliance to the Building Control Body of the noise constraints in Approved Document O. This guide provides clarity for practitioners and regulators so that assessments can be carried out consistently, and the outcome is repeatable and reliable.

Paragraph 3.3 of Approved Document O states that windows are likely to be closed during sleeping hours if noise within bedrooms exceeds the following limits:

- 40dB $L_{Aeq,T}$, averaged over 8 hours (between 11pm and 7am)
- 55dB L_{AFmax} , more than 10 times a night (between 11pm and 7am)

3.7 Acoustics Ventilation and Overheating Residential Design Guide 2020

The Acoustics, Ventilation and Overheating Guide (AVO) is intended to be used by acoustic practitioners as well as all those involved in the planning, development, design and commissioning of new dwellings.

It recommends an approach to acoustic assessments for new residential developments that take due regard of the interdependence of provisions for acoustics, ventilation and overheating. Application of the AVO Guide is intended to demonstrate good acoustic design as described in the ProPG, when considering internal noise level guidelines.

3.8 Recommended Noise Assessment Criteria

Based on the guidance above it is recommended that the following criteria would be reasonable with the aim of minimising the impact of the environmental noise on the proposed 28no. residential units:

- Daytime noise levels not to exceed 35dB $L_{Aeq, 16hr}$ in living rooms / bedrooms
- Daytime noise levels not to exceed 40dB $L_{Aeq, 16hr}$ in dining room / kitchen
- Night-time noise levels in bedrooms not to exceed 30dB $L_{Aeq, 8hr}$



- Night-time single sound events in bedrooms not to exceed 45dB L_{Amax} more than 15 times a night
- Noise levels in external amenity spaces to not exceed 50dB $L_{Aeq,T}$, with an upper guideline of 55dB $L_{Aeq,T}$ in noisier environments

Table 4, Note 5 of BS 8233:2014 states: 'If relying on closed windows to meet the guide values, there needs to be an appropriate alternative ventilation that does not compromise the façade insulation or the resulting noise level. If applicable, any room should have adequate ventilation (e.g. trickle ventilators should be open) during assessment.'

4.0 Assessment of Results

4.1 Assessment of Noise Risk

The following noise and overheating risk assessment highlights the level of risk of an adverse effect based on the guidance from the ProPG and AVO guidance documents.

The noise levels used in the risk assessment have been calculated using the SoundPLAN noise modelling software and represent the worst-case noise levels on each elevation.

Location	Time of Day	Calculated Noise Levels (dBA)	ProPG Risk of Adverse Effect	AVO Guide Risk (overheating) Category
North Flat Block Elevations (Second Floor)	Daytime $L_{Aeq, 16hr}$	68	Medium	High
	Night-time $L_{Aeq, 8hr}$	59	High/Medium	High
Rear Flat Block Elevations (Second Floor)	Daytime $L_{Aeq, 16hr}$	58	Low	Medium/Low
	Night-time $L_{Aeq, 8hr}$	50	Medium/Low	Medium/Low
North House Block Elevations (Second Floor)	Daytime $L_{Aeq, 16hr}$	64	Medium/Low	High/Medium
	Night-time $L_{Aeq, 8hr}$	56	Medium	High
Rear House Block Elevations (Second Floor)	Daytime $L_{Aeq, 16hr}$	60	Medium/Low	Medium
	Night-time $L_{Aeq, 8hr}$	51	Medium/Low	Medium/Low

Table 3 – Noise risk assessment for Queens Drive

As shown above, the façades directly facing Queens Drive would represent the most significant risk in terms of potential adverse impact.

Due to the overheating risk, dwellings with elevations facing Queens Drive will require an enhanced ventilation specification that would normally be offered by opening windows, however, the noise risk assessment indicates that relying on opening windows would result in significant noise intrusion, thus disrupting normal sleep.

The AVO guide gives the following example outcomes for noise that may be perceived as present and disruptive:

"Having to keep windows closed most of the time because of the noise. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in

getting back to sleep. Quality of life diminished due to change in acoustic character of the area."

It should be noted that ProPG does not account for daytime L_{Amax} instances that may arise from vehicles passing by. These instances may cause annoyance during the day to the potential residents. As such, extra mitigation has been recommended in order to minimise noise complaints to the premises.

4.2 SoundPLAN Model

Azymuth has undertaken acoustic modelling with the SoundPLAN noise modelling software to predict and visualise the impact of noise on the proposed 28no. residential units at Queens Drive.

4.2.1 Grid Noise Map (GNM)

Azymuth have produced the following daytime GNM to show the effect of traffic noise on the development site.




Figure 3 – Daytime GNM of Queens Drive

4.2.2 Façade Noise Map (FNM)

Azymuth have produced the following daytime FNMs to provide an indication of the façade noise levels incident on the proposed development blocks.




Figure 4 – Daytime FNM of Queens Drive, 3D view




Figure 5 – Daytime FNM of Queens Drive, 2D view



4.3 Assessment of Noise in External Amenity Spaces

The below table provides an indication of the noise levels predicted in external amenity spaces such as gardens and balconies/terraces.

The noise level from the worst-affected gardens/balconies have been shown below.

Receptor Location	Upper Guideline Noise Limit, $L_{Aeq,T}$ (dB)	Predicted Level, $L_{Aeq,T}$ (dB)
House Block Balconies	55	62-63
House Block Plot 28 garden	55	54

Table 4 – Predicted noise levels in external amenity spaces

The noise levels on the rear balconies of the house block plot shall exceed the upper guideline noise limit of 55dB $L_{Aeq,T}$ due to the proximity of the site to the surrounding motorways.

5.0 Recommendations for Noise Mitigation

Based on survey data and the predicted noise levels derived from SoundPLAN, Azymuth have produced the following recommendations in order to mitigate the effects of noise within the proposed development. If these recommendations are followed, noise levels within the development will satisfy the criteria as set out in Section 3.8.

NB all recommended mitigation specifications are subject to good workmanship and for materials to be installed as the manufacturer intends. Any poor workmanship may lead to weaknesses in the sound attenuation provided by the building elements.

5.1 Recommended Glazing Specification

The table below outlines the glazing specifications Azymuth would recommend in order to achieve the specified internal ambient noise level targets.

Glazing specifications have been colour coded relating to Figure 6.

Location (Habitable Spaces)	Glazing Specification	Appropriate Glazing Types
Elevations facing Queens Drive for both blocks (RED)	Any building regulations approved min. 36dB R_w and 32dB R_w+C_{tr}	Acoustic glazing e.g 6/16/6mm laminated good quality double glazed units
Rear elevations for both blocks (GREEN)	Any building regulations approved min. 29dB R_w and 25dB R_w+C_{tr}	Any good quality double glazed units

Table 5 – Azymuth recommended glazing specification for Queens Drive

5.2 Recommended Ventilation Specification

The table below outlines the recommended ventilation that should be paired with the glazing specifications to ensure the appropriate sound insulation targets are met. With reference to the AVO and ProPG guidance, Azymuth recommends the following ventilation specification to ensure sufficient air flow to dwellings whilst also achieving internal noise level targets.

Ventilation specifications have been colour coded relating to Figure 7.

Location (Habitable Spaces)	Ventilation Specification	Appropriate Ventilation Types
All dwellings (RED)	Any Building Regulations Approved Document F Continuous Mechanical Extract Ventilation with Trickle Vents	Trickle vents min. 38dB D_{new} e.g. Titon TA5223 (V50) + TA5005 (SF 418) 2500EA

Table 6 – Azymuth recommended ventilation specification for Queens Drive

5.3 Mitigation Specifications

Min. 36dB R_w and 32dB R_w+C_{tr}

Min. 29dB R_w and 25dB R_w+C_{tr}




Figure 6 – Glazing specifications for dwellings at Queens Drive

**MEV with Trickle vents min.
38dB D_{new}**




Figure 7 – Ventilation specification for dwellings at Queens Drive

The mitigation specifications shown above should be applied to all floors of the residential accommodation.

5.4 Other Elements of Building Envelope

Other elements of the building envelope should have the following sound insulation performance:

- External Walls: minimum sound insulation 55dB R_w . This minimum is likely to be significantly exceeded by a normal brickwork façade. Where alternative external wall types (eg composite cladding panels / Metsec build-ups) are proposed on habitable areas it will be appropriate to check whether they comply with the target 55dB R_w .
- Roof: minimum sound insulation 45dB R_w . This minimum would likely be exceeded with a traditional slate or tile roof with mineral wool loft insulation above plasterboard ceilings or by a suitably insulated concrete roof or composite flat roof. (NB for composite flat roof build-ups a minimum 200mm roof void and 100mm mineral wool insulation would be recommended over and above the rigid insulation required to provide the required levels of thermal insulation).



6.0 Summary

Azymuth has been contracted by MSV Housing to perform a Noise Impact Assessment (NIA) in relation to 28no. residential units to be located on Queens Drive, Rochdale. The main sources of noise affecting the site are road traffic from Queens Drive and the A664, which runs parallel to Queens Drive set back 3m to 8m.

A baseline noise survey has been undertaken in the vicinity of the site. Day-time ambient noise levels were measured to be between 68.2 – 65.0 $L_{Aeq,16hr}$ and night-time ambient noise levels were measured to be between 56.1 – 58.1 $L_{Aeq,8hr}$.

The development generally possesses a medium to high risk of adverse noise effect and overheating as per the ProPG and AVO guidance documents respectively.

Azymuth have produced a noise model in SoundPLAN 9.1 to better predict and visualise the effect of noise from road traffic noise on the development.

As such, Azymuth have provided the following recommendations to mitigate the effects of external noise in the internal areas of the development.

Glazing

- ➔ Elevations facing Queens Drive: min. 36dB R_w and 32dB R_w+C_{tr}
- ➔ Rear Elevations: min. 29dB R_w and 25dB R_w+C_{tr}

Ventilation

- ➔ All dwellings: MEV, Trickle vents min. 38dB D_{new}

Other Elements of Building Envelope

- ➔ External Walls: min. 55dB R_w
- ➔ Roof: min. 45dB R_w

If the above recommendations are to be adhered to then the noise levels in all dwellings shall satisfy the assessment criteria contained within Section 3.8.

Appendix A – Glossary of Acoustic Terms

Decibel (dB)

This is the unit used to measure sound. The human ear has an approximately logarithmic response to acoustic pressure over a very large dynamic range (typically 20 micro Pascal to 100 Pascal).

dB (A)

This is a measure of the overall noise level of sound across the audible spectrum with a frequency weighting (i.e. A-weighting) to compensate for the sensitivity of the human ear to sound of different frequencies. The A-weighting curve is implemented in sound level meters using an electronic filter that approximately corresponds to the frequency response of the ear.

Octave Band Noise Level

The human ear is sensitive to sound over a range of frequencies between approximately 20Hz to 20kHz. The ear is also generally more sensitive to medium and high frequencies than to low frequencies. In order to define the frequency content of a noise, the spectrum can be divided into frequency bands. The most commonly used frequency bands are octave bands, in which the mid-frequency of each band is twice that of the band below it.

L_{Aeq}

This is the equivalent steady sound level in dB(A) containing the same acoustic energy as the actual fluctuating sound level over a given time period.

Reverberation Time (RT or sometimes T_{30} or T_{60})

This is the time taken for the reverberant sound energy in an enclosure to decay one millionth of its equilibrium value, i.e. by 60dB, after the source has been switched off. The reverberation time is frequency dependent and it is customary to measure its value in octave or one-third octave bands. Reverberation occurs when sound waves are repeatedly reflected from each surface of the room.

Sound Reduction Index (SRI)

Difference measured between the amount of energy flowing towards the wall in the source room and the total amount of energy entering the receiving room (usual range 100 - 3150Hz for one third octave band values). The SRI varies with frequency and is measured in a laboratory in either octave or one-third octave bands.

$SRI = L_1 - L_2 + 10 \log (S/A)$, where:

L_1 = Noise level in the source room

L_2 = Noise levels in the receiving room

S = Surface area of test specimen

A = Equivalent acoustic absorption area in the receiving room

Weighted Sound Reduction Index (R_w)

This is a weighted single figure descriptor of the sound insulation performance of a partition measured under laboratory conditions. The procedure used to quantify the R_w is to compare the sound reduction index (SRI) in each of the one-third octave bands from 100Hz to 3150Hz against a set of standard reference curves.



Appendix B – Noise Survey Data

Start	Position	Time	L _{Amax}	L _{Aeq}	L _{A10}	L _{A50}	L _{A90}
Tuesday 26th Novemeber 2024							
12:57:59	1	00:05:00	81.5	65.2	67.9	60.2	57.6
13:02:59	1	00:05:00	81.0	65.6	68.8	60.1	57.3
13:07:59	1	00:05:00	79.4	65.0	68.4	59.9	56.8
13:12:59	1	00:05:00	78.3	63.8	66.5	59.1	56.8
13:19:46	2	00:05:00	80.5	65.1	66.6	62.2	59.3
13:24:46	2	00:05:00	80.9	65.5	66.9	62.2	59.8
13:29:46	2	00:05:00	78.6	65.7	68.4	62.6	60.2
13:34:46	2	00:05:00	84.7	67.3	70.7	62.7	59.9
13:41:19	3	00:05:00	82.2	67.9	70.5	66.3	61.2
13:46:19	3	00:05:00	83.9	67.5	70.2	65.6	61.9
13:51:19	3	00:05:00	81.1	68.5	70.6	66.1	61.9
13:56:19	3	00:05:00	80.0	69.2	72.5	67.2	63.3
14:02:48	1	00:05:00	75.9	63.9	67.9	59.1	55.9
14:07:48	1	00:05:00	77.6	64.3	67.6	60.7	58.2
14:12:48	1	00:05:00	75.4	64.2	68.6	59.9	57.1
14:17:48	1	00:05:00	77.4	64.6	68.8	59.5	57.3
14:23:49	2	00:05:00	83.9	66.5	67.9	62.7	60.4
14:28:49	2	00:05:00	78.9	65.8	68.9	62.7	60.4
14:33:49	2	00:05:00	81.5	66.9	70.1	62.7	60.5
14:38:49	2	00:05:00	80.7	66.9	70.0	62.5	59.7
14:45:08	3	00:05:00	81.9	68.3	70.9	66.0	60.1
14:50:08	3	00:05:00	78.6	68.0	71.4	65.9	61.0
14:55:08	3	00:05:00	80.5	68.4	71.2	66.8	62.4
15:00:08	3	00:05:00	79.2	67.4	70.9	64.6	59.8
15:12:03	2	00:05:00	79.0	65.3	67.8	62.0	59.7
15:17:03	2	00:05:00	77.2	66.2	70.2	62.8	59.9
15:22:03	2	00:05:00	79.5	67.0	70.7	62.5	59.8
15:27:03	2	00:05:00	82.9	65.8	69.1	62.1	60.4
15:32:49	1	00:05:00	79.9	64.5	68.5	58.9	55.1
15:37:49	1	00:05:00	80.5	65.9	69.5	61.9	56.9
15:42:49	1	00:05:00	81.2	65.4	68.9	60.3	56.3
15:47:49	1	00:05:00	81.1	66.8	71.0	63.2	56.2
15:54:39	3	00:05:00	80.1	68.8	72.3	66.2	60.9
15:59:39	3	00:05:00	78.3	68.4	71.7	66.7	61.5
16:04:39	3	00:05:00	77.1	68.0	71.5	65.7	60.7
16:09:39	3	00:05:00	80.2	68.1	72.2	65.4	60.5
Monday 2nd Decemeber 2024							
23:05:00	1	00:05:00	73.6	54.9	55.2	51.7	48.3
23:10:00	1	00:05:00	73.7	57.8	57.8	53.1	50.0
23:15:00	1	00:05:00	78.0	60.9	61.3	54.3	49.8
23:20:00	1	00:05:00	75.1	57.0	57.3	53.3	49.9
23:25:00	1	00:05:00	71.7	55.0	56.0	53.0	48.9
23:32:00	2	00:05:00	62.1	54.9	58.7	53.3	46.8
23:37:00	2	00:05:00	63.0	53.6	57.4	50.8	44.2
23:42:00	2	00:05:00	72.8	54.4	56.9	50.8	45.3



Start	Position	Time	L _{Amax}	L _{Aeq}	L _{A10}	L _{A50}	L _{A90}
23:47:00	2	00:05:00	78.7	56.1	56.5	49.2	41.7
23:52:00	2	00:05:00	80.2	59.2	57.2	50.1	43.2
23:59:00	3	00:05:00	76.2	57.4	59.9	47.6	43.2
Tuesday 3rd Decemeber 2024							
00:04:00	3	00:05:00	75.8	57.9	61.1	51.6	43.4
00:09:00	3	00:05:00	79.2	58.1	57.7	49.8	44.4
00:14:00	3	00:05:00	75.2	56.3	59.8	50.1	43.0
00:19:00	3	00:05:00	76.1	59.8	61.9	52.0	43.9

Table B1 – Fully tabulated noise measurement results