

Officer Report

Case Reference: PL/2026/0109
Location: 36 THAMES ROAD, MILNROW, ROCHDALE, OL16 3UB
Proposal: Application for a certificate of lawfulness for single storey rear and side dormer extension
Recommendation: Approve
Officer: Rosalind Gralton

PROPOSAL

Certificate of lawfulness is sought for the erection of a flat roof dormer to the side roof slope of the dwelling and a single storey rear extension. Rooflights to the existing roofslope are also proposed. The measurements are as follows:

Flat roof dormer: 5.96m (W), 1.7m (H), 3.7m (D). The proposed cubic volume is 18.74m³.

Single storey rear extension: 1.5m to eaves height, 3m in projection, 8.06m in width).

2 rooflights flush with the plane of the roof are also proposed.

Is the proposal wholly within the curtilage of the dwellinghouse? Yes

Relevant History: N/A

Permitted Development Rights removed? No

Representations

In accordance with the Council's code for publicity for this type of application, no letters of notification have been issued.

Legislation and Guidance

The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Permitted development rights for householders – Technical Guidance (Sept 2019)

Assessment (Class A)

Class A of Part 1 of Schedule 2 of the GPDO allows for the enlargement, improvement or other alteration of a house subject to it not being contrary to any of the following criteria:

(a) Permission to use the dwellinghouse as a dwelling has not been granted only by virtue of Class M,N,P, PA or Q of Part 3 of the GPDO

Complies

(b) As a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse).

Complies

(c) The height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse;

Complies

(d) The height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse;

Complies

(e) The enlarged part of the dwellinghouse would extend beyond a wall which—

(i) forms the principal elevation of the original dwellinghouse; or

(ii) fronts a highway and forms a side elevation of the original dwellinghouse;

Complies

(f) Subject to Paragraph (g), the enlarged part of the dwellinghouse would have a single storey and extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or exceed 4 metres in height.

Complies

(g) For a dwellinghouse not on article 2(3) land or a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and –

(i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or

(ii) exceed 4 metres in height.

Complies

(h) The enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or be within 7 metres of any boundary of the curtilage of the dwellinghouse opposite the rear wall of the dwellinghouse.

Complies

(i) The enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres.

Complies

(j) The enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would exceed 4 metres in height, have more than a single storey or have a width greater than half the width of the original dwellinghouse; or

Complies - as far as practically can be ascertained, the garage to the side elevation appears to be original to the dwelling as constructed. Neighbouring dwellings with identical garages to the side elevation.

(ja) (any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j);

Complies

(k) it would consist of or include

(i) the construction or provision of a veranda, balcony or raised platform,

(ii) the installation, alteration or replacement of a microwave antenna,

(iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or

(iv) an alteration to any part of the roof of the dwellinghouse

Complies

(A.2) In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if –

(a) it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;

(b) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse;

(c) the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse; or

(ca) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (b) and (c)

Complies

Conditions

Paragraph A.3 of the above order stipulates that development is permitted by Class A subject to the following conditions-

(a) The materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

Complies - submitted plans and application form indicate that this is to be the case.

(b) Any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be-

i. Obscure-glazed, and

ii. Non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and

Complies

(c) Where the enlarged part of the dwellinghouse has more than a single storey, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

Complies

Assessment (Class B)

Class B of Part 1 of the Schedule to the GPDO allows for the enlargement of a dwellinghouse consisting of an addition or alteration to its roof subject to it not being contrary to any of the following criteria:

(a) Permission to use the dwellinghouse as a dwelling has not been granted only by virtue of Class M,N,P, PA or Q of Part 3 of the GPDO

Complies

(b) Any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;

Complies

(c) Any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and front a highway;

Complies

(d) The cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than-

(i) 40 cubic metres in the case of a terrace house, or

(ii) 50 cubic metres in any other case;

Complies

(e) It would consist of or include –

(i) The construction or provision of a veranda, balcony or raised platform, or

(ii) The installation, alteration or replacement of a chimney, flue or soil and vent pipe; or

Complies

(f) The dwellinghouse is on article 2(3) land.

Complies

Conditions (Class B)

Development is permitted by Class B subject to the following conditions –

(a) The materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

Complies

(b) The enlargement must be constructed so that –

(i) Other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension

(aa) The eaves of the original roof are maintained or reinstated; and

(bb) The edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and

(ii) Other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and

Complies

(c) Any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be –

(i) Obscure-glazed, and

(ii) Non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed

Complies

Assessment (Class C)

Class C of Part 1 of Schedule 2 of the GPDO allows for any other alteration to the roof of the dwellinghouse subject to it not being contrary to any of the following criteria:

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (change of use)

Complies

(b) the alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof

Complies

(c) it would result in the highest part of the alteration being higher than the highest part of the original roof; or

Complies

(d) it would consist of or include-

(i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or

(ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment

Complies

Conditions (Class C)

Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse shall be -

(a) obscure-glazed; and

(b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed

Complies

Recommendation: Approve

Approval Reason(s) (1)

- 1 The proposal constitutes permitted development by virtue of compliance with the requirements of Schedule 2, Part 1, Classes A, B and C of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Informatives (1)

For the avoidance of doubt, the decision relates to the following drawings:-

1

- Site Location Plan
- Existing and Proposed Block Plan 26.3728.3
- Proposed Details - 26.3728.2D
- Existing Details - 26.3728.1