

M.P.S. INSTALLATIONS

ENVIRONMENTAL ENGINEERS: WASTE & SURFACE WATER TREATMENT

SURVEY REPORT

DATE: 16th January 2026

CLIENT: Vernon Wharmby

SITE ADDRESS: Lower Townhouse Barn, Townhouse Road, Littleborough, OL15 9JX

REPORT: Survey on septic tank at the above property and shared with other properties. The septic tank serves eight properties in total. On inspection it was found to be a brick-built septic tank and filter bed. No visible signs of flooding. Brick work looks in good condition and filter bed is also working in good order.

Conclusion: The tank is in a satisfactory condition and with the outfall discharging into a working filter bed the system is compliant with the general binding rules 2020

Yours sincerely



J Shackleton

Environmental Consultant

M.P.S INSTALLATIONS LTD

8, Grange Road, Cliviger, Burnley, BB10 4SS Tel: 01282 412054 Mobile: 07831537505

Vat Reg No: 361407963 Company No: 5147576