

Application Number:	25/00091/CPL
Location:	71 Park Road, Rochdale, OL12 9BP
Proposal:	Rear dormer extension and hip-to-gable roof extension
Applicant:	Mr Abdul Wakas
Case Officer:	Hamish Rigg
Recommendation:	Grant

Location

The application relates to no. 71 Park Road; a two-storey end of terrace dwelling on the outskirts of Rochdale town centre. Park Road is a residential street comprising houses of a similar design and material palette. No. 71 and the adjoining/ adjacent houses are set back from the adopted highway and arranged in a crescent formation.

No. 71 faces east, overlooking its driveway and large grass verge. It adjoins no. 69 to the south, and borders the curtilage of no. 73 to the north. The rear boundary of the curtilage faces west, bordering Hey Brook and an area of woodland.

Description of Proposal

Permission is sought for a hip-to-gable roof extension together with the erection of a flat roof rear dormer. Proposed materials include matching concrete roof tiles and panels. The dormer would measure 4.3m (width) X 3.5m (depth) 2.3m (height).

Is the proposal wholly within the curtilage of the dwellinghouse?	Yes
--	-----

Relevant History:

25/00090/HOUS – pending consideration

Two storey side and single storey rear extensions including roof lights following removal of existing conservatory.

Permitted Development Rights removed?	Original permission not located
--	---------------------------------

Representations

In accordance with the Council's code for publicity for this type of application, no letters of notification have been issued.

Legislation and Guidance

The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Permitted development rights for householders – Technical Guidance (September 2019)

Assessment (Class B)

Class B of Part 1 of the Schedule to the GPDO allows for the enlargement of a dwellinghouse consisting of an addition or alteration to its roof subject to it not being contrary to any of the following criteria:

- (a) Permission to use the dwellinghouse as a dwelling has not been granted only by virtue of Class M,N,P, PA or Q of Part 3 of the GPDO

☒ **Complies**

☐ **Does Not Comply**

- (b) Any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;

☒ **Complies**

☐ **Does Not Comply**

- (c) Any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and front a highway;

☒ **Complies**

☐ **Does Not Comply**

- (d) The cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than-
- (i) 40 cubic metres in the case of a terrace house, or
 - (ii) 50 cubic metres in any other case;

☒ **Complies**

☐ **Does Not Comply**

Dormer Volume Calculation

Height (m)	2.3
-------------------	------------

Depth (m)	3.5
Length (m)	4.3
Total (m ³)	17.31

Hip to Gable Volume Calculation

Gable End Height (m)	2.7
Gable End Width (m)	8.4
Depth (m)	3.8
Total (m ³)	14.36

(e) It would consist of or include –

- (i) The construction or provision of a veranda, balcony or raised platform, or
- (ii) The installation, alteration or replacement of a chimney, flue or soil and vent pipe; or

☒ **Complies**

☐ **Does Not Comply**

(f) The dwellinghouse is on article 2(3) land.

☒ **Complies**

☐ **Does Not Comply**

Conditions (Class B)

Development is permitted by Class B subject to the following conditions –

- (a) The materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

☒ **Complies**

☐ **Does Not Comply**

☐ **Details not provided**

(b) The enlargement must be constructed so that –

- (i) Other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension
 - (aa) The eaves of the original roof are maintained or reinstated; and
 - (bb) The edge of the enlargement closest to the eaves of the

original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and

- (ii) Other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and

☒ **Complies**

☐ **Does Not Comply**

☐ **Details not provided**

- (c) Any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be –

- (i) Obscure-glazed, and
(ii) Non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed

☒ **Complies**

☐ **Does Not Comply**

☐ **Details not provided**

Recommendation:

Grant

The proposal constitutes permitted development by virtue of compliance with the requirements of Schedule 2, Part 1, Class B of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Notes for applicant:

For the avoidance of doubt, the decision relates to the following drawings:-

- Proposed elevations, floor plans, and site plans: A 2249/2
- Location plan

	Date	Officer
Report Completed	26/03/2025	Signed: Hamish Rigg
Authorisation	28/03/2025	Signed: RG