

Application Number:	25/00174/CPL
Location:	10 Manor Road Middleton Rochdale M24 1JZ
Proposal:	Certificate of lawfulness for a proposed hip to gable dormer loft conversion.
Applicant:	Mr Mark Symington
Case Officer:	Aimee Bovaird
Recommendation:	Approve

CHECKED AND SIGNED OFF BY: TH

DATE: 16/04/2025

Location

The application relates to 10 Manor Road, a two storey semi-detached house within the Defined Urban Area. The dwelling benefits from off street parking, front and rear amenity space.

Description of Proposal

A certificate of lawfulness is sought for a proposed hip to gable dormer loft conversion and a rear dormer.

Is the proposal wholly within the curtilage of the dwellinghouse?	Yes
--	-----

Relevant History:

25/00031/HOUS - Single storey rear extension and alteration to fenestration - Approved

Permitted Development Rights removed?	No
--	----

Representations

In accordance with the Council's code for publicity for this type of application, no letters of notification have been issued.

Legislation and Guidance

The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Permitted development rights for householders – Technical Guidance (Sept 2019)

Assessment (Class B)

The proposed development consists of altering the roof from a hip to gable and adding a dormer for a loft conversion.

Class B of Part 1 of the Schedule to the GPDO allows for the enlargement of a dwellinghouse consisting of an addition or alteration to its roof subject to it not being contrary to any of the following criteria:

- (a) Permission to use the dwellinghouse as a dwelling has not been granted only by virtue of Class M,N,P, PA or Q of Part 3 of the GPDO

☒ **Complies**

☐ **Does Not Comply**

- (b) Any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;

☒ **Complies**

☐ **Does Not Comply**

- (c) Any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;

☒ **Complies**

☐ **Does Not Comply**

- (d) The cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than-
- (i) 40 cubic metres in the case of a terrace house, or
 - (ii) 50 cubic metres in any other case;

☒ **Complies**

☐ **Does Not Comply**

Hip to gable volume = 7.02 m³
Dormer Volume Calculation = 25.5 m³

Total = 32.7m³

- (e) It would consist of or include –
- (i) The construction or provision of a veranda, balcony or raised platform, or
 - (ii) The installation, alteration or replacement of a chimney, flue or soil and vent pipe; or

☒ **Complies**

☐ **Does Not Comply**

(f) The dwellinghouse is on article 2(3) land.

☒ **Complies**

☐ **Does Not Comply**

Conditions (Class B)

Development is permitted by Class B subject to the following conditions –

(a) The materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

☒ **Complies**

☐ **Does Not Comply**

☐ **Details Not Provided**

(b) The enlargement must be constructed so that –

(i) Other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension

(aa) The eaves of the original roof are maintained or reinstated; and

(bb) The edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and

(ii) Other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse;

☒ **Complies**

☐ **Does Not Comply**

☐ **Details Not Provided**

(c) Any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be –

(i) Obscure-glazed, and

(ii) Non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed;

☒ **Complies**

☐ Does Not Comply

☐ Details Not Provided

Assessment (Class C)

Class C of Part 1 of the Schedule to the GPDO allows for other alterations to the roof of a house subject to it not being contrary to any of the following criteria:

- (a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (change of use)

☒ Complies

☐ Does Not Comply

- (b) the alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof

☒ Complies

☐ Does Not Comply

- (c) it would result in the highest part of the alteration being higher than the highest part of the original roof; or

☒ Complies

☐ Does Not Comply

- (d) it would consist of or include-
- (i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
 - (ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
 - (iii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment

☒ Complies

☐ Does Not Comply

Conditions (Class C)

Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse shall be

- (a) obscure-glazed; and

☒ **Complies**

☐ **Does Not Comply**

(b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed

☒ **Complies**

☐ **Does Not Comply**

Recommendation: Approve

The proposal constitutes permitted development by virtue of compliance with the requirements of Class B and Class C of Part 1 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Notes for applicant:

For the avoidance of doubt, the decision relates to the following drawings:-

- Proposed Ground Floor Plan 928-108
- Proposed First Floor Plan 928-109
- Proposed Loft Floor Plan 918-110
- Proposed Roof Plan 928-111
- Proposed Elevations 928-112

	Date	Officer
Report Completed	10/04/2025	Signed: AB
Authorisation	16/04/2025	Signed: TH

Report Author Aimee Bovaird