

APPLICATION NUMBER: 22/01277/CPL

Application Number:	22/01277/CPL
Location:	17 Hawthorn Road, Rochdale, OL11 5JG
Proposal:	Certificate of lawfulness for a single storey rear extension following removal of existing conservatory
Applicant:	Miss Hayley Warrender
Case Officer:	Sam Yuen
Recommendation:	Grant

CHECKED AND SIGNED OFF BY:

DATE:

Location

The application relates to no. 17 Hawthorn Road, a two-storey detached dwelling in the ward of Bamford. The dwelling is adjacent to no. 19 Hawthorn Road to the north, adjacent to no. 15 Hawthorn Road to the south, and faces the highway to the north-east. The rear boundary of the curtilage borders a private driveway.

Description of Proposal

Certificate of lawfulness is sought for a single storey rear extension following the removal of the existing conservatory. The extension projects 3m from the rear elevation of the host dwelling and has a maximum height of approx. 3.46m and an eaves height of 3m.

Is the proposal wholly within the curtilage of the dwellinghouse?	Yes
--	-----

Relevant History: N/A

Permitted Development Rights removed?	N/A
--	-----

Representations

In accordance with the Council's code for publicity for this type of application, no letters of notification have been issued.

Legislation and Guidance

The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Permitted development rights for householders – Technical Guidance (Sept 2019)

Assessment (Class A)

Class A of Part 1 of Schedule 2 of the GPDO allows for the enlargement, improvement or other alteration of a house subject to it not being contrary to any of the following criteria:

- (a) Permission to use the dwellinghouse as a dwelling has not been granted only by virtue of Class M,N,P, PA or Q of Part 3 of the GPDO

☒ **Complies**

☐ **Does Not Comply**

- (b) As a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse).

☒ **Complies**

☐ **Does Not Comply**

- (c) The height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse.

☒ **Complies**

☐ **Does Not Comply**

- (d) The height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse.

☒ **Complies**

☐ **Does Not Comply**

- (e) The enlarged part of the dwellinghouse would extend beyond a wall which -
(i) Forms the principal elevation or
(ii) Fronts a highway and forms a side elevation of the original dwellinghouse.

☒ **Complies**

☐ **Does Not Comply**

- (f) Subject to Paragraph (g), the enlarged part of the dwellinghouse would have a single storey and extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or exceed 4 metres in height.

☒ **Complies**

☐ **Does Not Comply**

The host dwelling is a detached property and therefore eligible for a 4m extension. The plans indicate a projection of 3m.

(g) For a dwellinghouse not on article 2(3) land or a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and –

- (i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or
- (ii) exceed 4 metres in height.

☒ **Complies**

☐ **Does Not Comply**

Note – This application does not propose a larger home extension and paragraph (g) is therefore not applicable.

(h) The enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or be within 7 metres of any boundary of the curtilage of the dwellinghouse opposite the rear wall of the dwellinghouse.

☒ **Complies**

☐ **Does Not Comply**

Note – This application does not propose an extension with more than a single storey and paragraph (h) is therefore not applicable.

(i) The enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres.

☒ **Complies**

☐ **Does Not Comply**

The height to eaves is 3m.

(j) The enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would exceed 4 metres in height, have more than a single storey or have a width greater than half the width of the original dwellinghouse; or

☒ **Complies**

☐ **Does Not Comply**

(ja) (any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j));

☒ **Complies**

☐ **Does Not Comply**

(k) it would consist of or include

- (i) the construction or provision of a veranda, balcony or raised platform,
- (ii) the installation, alteration or replacement of a microwave antenna,
- (iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
- (iv) an alteration to any part of the roof of the dwellinghouse

☒ **Complies**

☐ **Does Not Comply**

- ☐ **The plans do not include a balcony or raised platform**
- ☐ **The plans do not include the alteration of a microwave antenna**
- ☐ **The plans do not include the alteration or installation of a soil and vent pipe**
- ☐ **The plans do not include the alteration to any part of the roof of the dwellinghouse**

Finally, paragraph A.3 of the above order stipulates that development is permitted by Class A subject to the following conditions-

- a. The materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;
- b. Any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be-
 - i. Obscure-glazed, and
 - ii. Non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and
- c. Where the enlarged part of the dwellinghouse has more than a single storey, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

The proposed materials for construction would be similar in appearance to the exterior of the existing dwellinghouse and consists of a single storey extension.

Recommendation: Grant

The proposal constitutes permitted development by virtue of compliance with the requirements of Schedule 2, Part 1, Class A of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Notes for applicant:

For the avoidance of doubt, the decision relates to the following drawings:-

- Location Plan
- Existing Site Plan
- Proposed Site Plan
- Existing and Proposed Floor Plans and Elevations – 3166-01

	Date	Officer
Report Completed	22/11/2022	Signed: SY
Authorisation	28/11/2022	Signed: RK

Report Author Sam Yuen