

Application Number:	25/00788/CPL
Location:	8 Dorset Close, Heywood, OL10 3JA
Proposal:	Application for a certificate of lawfulness for a proposed rear dormer and internal alterations
Applicant:	David Mills
Case Officer:	Bob Melling
Recommendation:	Grant

Location

This application relates to no. 8 Dorset Close, a semi-detached bungalow located in a residential area of Heywood.

Description of Proposal

The application seeks a certificate of lawfulness for a proposed rear dormer.

Is the proposal wholly within the curtilage of the dwellinghouse?	Yes
--	-----

Relevant History:

25/00679/HOUS: Single-storey side extension, alteration to fenestration to side and rear following demolition to existing garage. **Pending determination.**

Permitted Development Rights removed?	No
--	----

Representations

In accordance with the Council's code for publicity for this type of application, no letters of notification have been issued.

Legislation and Guidance

The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Permitted development rights for householders – Technical Guidance (September 2019).

Assessment (Class B)

Class B of Part 1 of the Schedule to the GPDO allows for the enlargement of a dwellinghouse consisting of an addition or alteration to its roof subject to it not being contrary to any of the following criteria:

- (a) Permission to use the dwellinghouse as a dwelling has not been granted only by virtue of Class M, N,P, PA or Q of Part 3 of the GPDO;

☒ **Complies**

☐ **Does Not Comply**

- (b) Any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;

☒ **Complies**

☐ **Does Not Comply**

- (c) Any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;

☒ **Complies**

☐ **Does Not Comply**

- (d) The cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than-
- (i) 40 cubic metres in the case of a terrace house, or
 - (ii) 50 cubic metres in any other case;

☒ **Complies**

☐ **Does Not Comply**

Officer's calculations - Dormer Volume Calculation

Height (m)	2.27
Depth (m)	2.53
Length (m)	7.85
Total (m³)	22.54

- (e) It would consist of or include –
- (i) The construction or provision of a veranda, balcony or raised platform, or
 - (ii) The installation, alteration or replacement of a chimney, flue or soil and vent pipe; or

☒ **Complies**

☐ **Does Not Comply**

(f) The dwellinghouse is on article 2(3) land.

☒ **Complies**

☐ **Does Not Comply**

Conditions (Class B)

Development is permitted by Class B subject to the following conditions –

(a) The materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

☒ **Complies**

☐ **Does Not Comply**

☐ **Details not provided**

(b) The enlargement must be constructed so that –

(i) Other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension

(aa) The eaves of the original roof are maintained or reinstated; and

(bb) The edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and

(ii) Other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and

☒ **Complies**

☐ **Does Not Comply**

☐ **Details not provided**

(c) Any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be –

(i) Obscure-glazed, and

(ii) Non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed

☒ **Complies**

☐ **Does Not Comply**

☐ **Details not provided**

Recommendation: Grant

The proposal constitutes permitted development by virtue of compliance with the requirements of Schedule 2, Part 1, Class B of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Notes for applicant:

For the avoidance of doubt, the decision relates to the following drawings:-

- Site Location Plan
- Existing Floor Plans. Dwg no. 25.3566.1A
- Existing Elevations. Dwg no. 25.3566.3
- Scheme 5 Proposed Floor Plans. Dwg no. 25.3566.SC5.1A
- Scheme 5 Proposed Elevations. Dwg no. 25.3566.SC5.2A

	Date	Officer
Report Completed	15/08/2025	Signed: BM
Authorisation	15.09.25	Signed: AC

Report Author Bob Melling