

Application Number:	25/00972/CPL
Location:	58 Mossway, Middleton, Rochdale, M24 1NS
Proposal:	Application for a certificate of lawfulness for a proposed rear dormer extension and hip-to-gable roof extension
Applicant:	Mrs Kelly Burns
Case Officer:	Sam Yuen
Recommendation:	Grant

CHECKED AND SIGNED OFF BY: AC

DATE: 30/10/25

Location

The application relates to no. 58 Mossway, a two-storey semi-detached dwelling located in Alkrington. The dwelling is adjoined by no. 56 Mossway to the west, adjacent to no. 60 Mossway to the east, and faces the highway to the north. The rear curtilage boundary backs onto the M60 to the south.

Description of Proposal

Certificate of lawfulness is sought for an enlargement of the roof space including a flat roof dormer extension to the rear roof slope which measures 5.44m in length, 2.27m in height and 3.5m in depth; as well as a hip-to-gable roof extension.

The submitted plans also indicate the alteration of the soil and vent pipe.

Is the proposal wholly within the curtilage of the dwellinghouse?

Yes

Relevant History:

25/00695/HOUS - Hip to gable, flat roof, rear dormer extension – Withdrawn

Permitted Development Rights removed?

Cannot locate original permission

Representations

In accordance with the Council's code for publicity for this type of application, no letters of notification have been issued.

Legislation and Guidance

The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Permitted development rights for householders – Technical Guidance (Sept 2019)

Assessment (Class B)

Class B of Part 1 of the Schedule to the GPDO allows for the enlargement of a dwellinghouse consisting of an addition or alteration to its roof subject to it not being contrary to any of the following criteria:

- (a) Permission to use the dwellinghouse as a dwelling has not been granted only by virtue of Class M,N,P, PA or Q of Part 3 of the GPDO

☒ **Complies**

☐ **Does Not Comply**

- (b) Any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;

☒ **Complies**

☐ **Does Not Comply**

- (c) Any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and front a highway;

☒ **Complies**

☐ **Does Not Comply**

- (d) The cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than-
- (i) 40 cubic metres in the case of a terrace house, or
 - (ii) 50 cubic metres in any other case;

☒ **Complies**

☐ **Does Not Comply**

Dormer Volume Calculation

Height (m)	2.27
Depth (m)	3.5
Length (m)	5.44
Total (m³)	21.61

Hip to Gable Volume Calculation

Gable End Height (m)	2.56
Gable End Width (m)	7.89
Depth (m)	3.25
Total (m³)	10.94

Total volume = $21.61\text{m}^3 + 10.94\text{m}^3 = \underline{32.55\text{m}^3}$

(e) It would consist of or include –

- (i) The construction or provision of a veranda, balcony or raised platform, or
- (ii) The installation, alteration or replacement of a chimney, flue or soil and vent pipe; or

☒ **Complies**

☐ **Does Not Comply**

Note: The submitted plans indicate the alteration of a soil and vent pipe. However, such works may be considered under Class G of permitted development rights.

(f) The dwellinghouse is on article 2(3) land.

☒ **Complies**

☐ **Does Not Comply**

Conditions (Class B)

Development is permitted by Class B subject to the following conditions –

- (a) The materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

☒ **Complies**

☐ **Does Not Comply**

☐ **Details Not Provided**

(b) The enlargement must be constructed so that –

- (i) Other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension
 - (aa) The eaves of the original roof are maintained or reinstated; and
 - (bb) The edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the

eaves, measured along the roof slope from the outside edge of the eaves; and

- (ii) Other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and

☒ **Complies**

☐ **Does Not Comply**

☐ **Details Not Provided**

- (c) Any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be –

- (i) Obscure-glazed, and
(ii) Non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed

☒ **Complies**

☐ **Does Not Comply**

☐ **Details Not Provided**

Assessment (Class G)

Class G of Part 1 of Schedule 2 of the GPDO allows for the installation, alteration or replacement of a chimney, flue or soil and vent pipe on a dwellinghouse subject to it not being contrary to any of the following criteria:

- a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (change of use)

☒ **Complies**

☐ **Does Not Comply**

- b) the height of the chimney, flue or soil and vent pipe would exceed the highest part of the roof by 1 metre or more; or

☒ **Complies**

☐ **Does Not Comply**

- c) in the case of a dwellinghouse on article 2(3) land, the chimney, flue or soil and vent pipe would be installed on a wall or roof slope which-

- (i) fronts a highway, and
- (ii) forms either the principal elevation or a side elevation of the dwellinghouse.

☒ **Complies**

☐ **Does Not Comply**

Recommendation: Grant

The proposal constitutes permitted development by virtue of compliance with the requirements of Schedule 2, Part 1, Class B and Class G of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended).

Notes for applicant:

For the avoidance of doubt, the decision relates to the following drawings:-

- Location Plan and Existing Site Plan – drawing no. DR-001 rev. P02 received 22/09/2025
- Proposed Site Plan – drawing no. DR-003 rev. P03 received 22/09/2025
- Existing Floor Plans and Elevations – drawing no. DR-001 rev. P01 received 22/09/2025
- Proposed Floor Plans and Elevations – drawing no. DR-004 rev. P03 received 22/09/2025

	Date	Officer
Report Completed	24/10/2025	Signed: SY
Authorisation	30/10/2025	Signed: AC

Report Author Sam Yuen