








Site Address:	Rochdale Rd, Middleton, Manchester M24 6XH
Solar PV Installation Overview	344.94 kWp installation consisting of 644 x 540W PV Modules
Permitted Development Information	Solar PV modules must not protrude more than 0.2m beyond the plane of the roof slope when installed on a pitched roof Solar PV modules must not protrude more than 1 meter above the highest part of the roof when installed on a flat roof The solar PV equipment must not be installed within 1 meter of the external edge of the roof Further information can be found at https://www.legislation.gov.uk/ukxi/2015/596/schedule/2/part/14/crossheading/class-j-installation-or-alteration-etc-of-solar-equipment-on-nondomestic-premises
Roof type	Flat and Pitched Roof Design
Mounting System type	Esdec flatfix east/west and Clenergy standing Seam (additional information below)
Site / Design Images and Information	


Project Overview	
Site Location	

Roof Elevation Identification Plan	
Module installation plan (including 1m perimeter) Elevation 1 Additional images shown in appendix A	

Module installation plan (including 1m perimeter) Elevation 2 Additional images shown in appendix B	
Module installation plan (including 0.2m perimeter) Elevation 3 Additional images shown in appendix C	

Module installation plan (including 0.2m perimeter) Elevation 4 Additional images shown in appendix D	
Module installation plan (including 0.2m perimeter) Elevation 5 Additional images shown in appendix E	

Module Dimensions	Length - 2063 mm / Width - 1134 mm / Frame Depth - 30mm  unit: mm
Mounting Dimensions	 Esdec FlatFix East / West Orientation flat roof mounting system Finished protrusion height of solar panels above existing roof plane - <0.5m  Protrusion height from roof plane: 450mm




System Declaration

I confirm that the above information is true and accurate and that to the best of my knowledge the project specification outlined above satisfies the requirements of the Town and Country Planning (General Permitted Development) (England) Order 2015 (Update 21/12/2023) Class J – Installation or alteration of solar equipment on non-domestic premises.


Signed

Ben Nuttall
System Designer
NPS Energy Ltd
Completion of report

Appendix A




This image shows the panels are 245cm from external edge A.




This image shows the panels are 190cm from external edge B.


Appendix B




This image shows the panels are 130cm from external edge A.




This image shows the panels are 200cm from external edge B.




This image shows the panels are 110cm from external edge C.



This image shows the panels are 900cm from external edge D.




This image shows the panels are 130cm from external edge E.




This image shows the panels are 300cm from external edge F.


Appendix C



This image shows the panels are 190cm from external edge A.




This image shows the panels are 205cm from external edge B.




This image shows the panels are 110cm from external edge C.

Appendix D




This image shows the panels are 140cm from external edge A.




This image shows the panels are 135cm from external edge B


Appendix E



This image shows the panels are 280cm from external edge A



This image shows the panels are 265cm from external edge B



This image shows the panels are 400cm from external edge C