

United Utilities

With regards to the surface water hierarchy, we are utilising soakaways for both plots and highways where possible. The entrance road is to drain to an existing 1750dia. SW sewer via a new MH connection. We initially explored soakaways at the site entrance however, after discussions with Highways it was determined these had to be situated 5m away from any highway (attached), which we cannot achieve in this area. Additionally, the site entrance bellmouth is circa 150mm below the lowest point to the watercourse so it wouldn't be possible for this section of highway to drain via gravity to the watercourse. Therefore, a new connection to the existing 1750dia. SW sewer was considered the most feasible option.