

New Carriageway & Footpath Construction is to be strictly in accordance with Rochdale Council Specification for Estate Roads

Adoptable Road Construction

Section 38/278 construction build up by others.

Parking Bays/Driveways (Permeable AC Car Park Bays - max vehicle GLW = 3500 kg)

- Surface Course - 30mm thickness AC - 10 open surface to BS EN 13108-1
- Binder Course - 70mm thickness of AC - 20 open bin to BS EN 13108-1
- Geotextile - Inbitex (by WTB Geotechnics Ltd)
- Sub-Base - 250mm thick 40 - 4mm "No fines" to clause 1.25 (Assumes a min CBR value of 3.5%)
- Geotextile - SC Intergrid (by WTB Geotechnics Ltd)
- Formation - Remove all topsoil and vegetable matter and roll formation (DoT clause 616).

Footpath Construction

- Surface Course - 20mm thickness of AC6 Dense Surface Macadam. Finish to be Black
- Binder Course - 60mm thickness of Close Graded Asphalt -20 mm nominal size (DoT clause 906)
- Sub-Base - 100mm DoT type 2 Sub-Base Material (DoT clause 804)
- Formation - Remove all topsoil and vegetable matter and roll formation (DoT clause 616).

NOTES:

1. Do not scale from this drawing.
2. This drawing is copyright and is sent to you in confidence. It must not be copied, used or disclosed, in whole or in part, to third parties without written permission. It remains the property of Booth King Partnership Ltd. (BKPL) and must be returned on request.
3. This drawing is to be read in conjunction with all relevant contractual documents.
4. Anyone using this drawing must be aware of their legal duties under the CDM Regulations 2015, refer to the HSE website for further information. BKPL are not Principal Designers.
5. All dimensions shown on this drawing are in millimeters unless noted otherwise.
6. If the Contractor consider that they do not have sufficient information to safely complete the works detailed on this drawing, they should contact the Engineer.
7. This document uses revision codes in accordance with ISO EN 19650:
   P. Preliminary (non-contractual) - review, comment or approval.
   C. Contractual - Approved for stage completion.
8. This document uses status codes in accordance with ISO EN 19650:
   Work in progress:
   S0 - WIP
   Shared (non-contractual):
   S1 - Coordination, **S2** - Information, **S3** - Review, **S4** & **S5** - Approval.
   Published (contractual):
   A1, **An**, etc. (where "n" relates to the project stage)
9. This document uses project stages in accordance with the IStructE Structural Plan of Work 2020:
   2 - Concept, **3** - Coordination, **4** - Technical Design,
   4.5 - Production Design, **5** - Construction, **6** - Handover.
10. Only documents with a revision code C# (where '#' relates to a revision number) and status code A4 or A5 are suitable for construction. Any deviations to that which is on site is not the liability of BKPL.

REV.	DATE	REVISION DETAILS	INITIALS
P01	24.04.26	Initial drawing issue	SM
		CURRENT DRAWING REVISION CHECKED BY	RM
		CURRENT DRAWING REVISION APPROVED BY	RM

DRAWING STATUS:	PROJECT STAGE:
S4	4

boothking PARTNERSHIP LIMITED

CONSULTING CIVIL & STRUCTURAL ENGINEERS

www.booth-king.co.uk office@booth-king.co.uk

RAMSBOTTOM Tel: 01706 822 022 | **MANCHESTER** Tel: 0161 694 7087 | **EDINBURGH** Tel: 0131 229 1547

PROJECT:

Bury Old Road, Heywood

TITLE:

External Works Finishes
Site 2

SCALE (A1)	AUTHOR	DATE	REVISION	BKPL No.
1:200	SM	Apr'26	P01	15959

DRAWING REF:

15959-BKP-XX-XX-DR-C-0703